



Note:

- 1..Material: 80g written paper;
- 2..Size: 11”L X W 8.5”
- 3..Color: black printing with double sides;
- 4.. folding method as below drawing;

Step1





**Self-Diagnostic Electronics Option
Operating Instructions**

Spectron Electronics
All Dual-Lite models ordered with the Spectron (I) option provide:

- Visual indication of AC power status
- Visual Indication of all self-diagnostic test cycles
- Visual indication of unit malfunctions including:
 - Battery fault
 - Charger fault
 - Transfer fault
 - Lamp fault
- User initiated test cycles of 1, 5, 30 or 60 minutes
- Temperature compensated charger for longer battery life
- 15 minute retransfer delay

LED Indicators
Two Status LED indicators, one red and one green are provided on the control panel of all models equipped with the Spectron option.

Red Service Alert LED
Under normal operating conditions, the Service Alert LED indicator will remain off. In the event the Spectron Controller detects a malfunction, the Service Alert LED will blink at a 1 Hz. rate based on the following table:

Red Status LED Code	Description
One blink ON/pause	Battery not connected
Two blinks ON/pause	Battery fault
Three blinks ON/pause	Charger fault
Four blinks ON/pause	Transfer circuit fault
Five blinks ON/pause	Emergency Lamp Fault

Green Operating Status LED
The green Operating Status LED serves as both an AC power and a self-test indicator. During normal operation, the Operating Status LED will be illuminated indicating the presence of AC power. During all automatic or manual self-test cycles, the Operating Status LED will blink at a 1 Hz. rate.

Manual Tests
Using the unit test switch, users can initiate different duration test cycles based on the following table:

Initiating Action	Test Cycle
Press test switch once	1 minute
Press test switch twice	5 minute
Press test switch 3 times	30 minute
Press test switch 4 times	60 minute


NOTE: Pressing test switch at any time after a test cycle has begun cancels remainder of test and returns unit to normal operation.

Lamp Sensing Adjustment Procedure
Procedure 1 - LZ30I-03L Model Only
LZ30I-03L model with the Spectron option are shipped from the factory with a load sensing jumper provided as shown in position "A" of the illustration below. In this position, Spectron's diagnostic circuitry can sense a failure in any of the unit's three connected lamps (2 integral and 1 remote).


IMPORTANT
If the third (remote) lighting head is not to be connected (for the purpose of extended run time or other reasons), the load sensing jumper must be reinstalled as shown in Position "B" below to prevent a false lamp failure indication. With the jumper in this position, the unit circuitry is enabled to sense a failure in either of the unit's two integral lamp heads.


Load Jumper Settings

"A"
(3 Lamp Position)



"B"
(2 Lamp Position)





Procedure 2 - All Other Remote Capacity Models
Dual-Lite remote capacity models provide sufficient battery power to operate the unit's two integral lighting heads plus one or more remote lighting fixtures. In order for the Spectron electronics module to detect a lamp failure in any of the connected fixtures, the lamp sensing circuit must be adjusted in the following manner:
NOTE: LZ30I-03L must be loaded to at least 15 watts using integral (built-in) and remote heads.

- Depending on the total amount of connected load, one of four different "RANGE" switch settings will need to be selected (See Fig. 1). Calculate the total connected wattage load and refer to the RANGE Switch Selector Chart below to determine the appropriate setting.
IMPORTANT: In calculating total connected load, be sure to include the wattage load of the unit's two integral lighting heads.

RANGE Switch Selector Chart

Total Connected Load Wattage	Load "RANGE" Switch Setting
15	1
16 - 30	2
(N/A) 31 - 45	3
(N/A) 46 - 60	4

FRONT

DR. NO.		SIZE: AD	
0603116			
SHEET	1	OF	3
		REV	C
TITLE			
INSTRUCTION SHEET			
TOLERANCES UNLESS OTHERWISE SPECIFIED .XX = ±.12"		DGHAL	
ANGLE TOL. ± 1°		DR. BY Emily Che	APP. BY
PROJECT NO.		TR. BY	SCALE
LZ		CHK. BY	DATE 06-12-2015

SUB	REVISIONS
1	06-12-2015, HECN15-00394, Emily Che newly release.
C	05-14-2021, HECN21-00272, Alyssa Yan Update Artwork.

DO NOT SCALE DRAWING
USE DIMENSIONS ONLY

"IN ACCEPTING OUR DRAWINGS OR BLUEPRINTS FOR QUOTATION OR OTHER PURPOSES, YOU AGREE NOT TO DISCLOSE TO OTHERS THE IDEAS, INFORMATION, OR DESIGNS THEREIN SHOWN, AND THAT YOU WILL MAKE NO USE OF OUR DRAWINGS OR BLUEPRINTS OR OF THE IDEAS, INFORMATION OR DESIGNS THEREIN SHOWN WITHOUT OUR PERMISSION."



Self-Diagnostic Electronics Option Operating Instructions

Spectron Electronics

All Dual-Lite models ordered with the Spectron (I) option provide:

- ❑ Visual indication of AC power status
- ❑ Visual Indication of all self-diagnostic test cycles
- ❑ Visual indication of unit malfunctions including:
 - Battery fault
 - Charger fault
 - Transfer fault
 - Lamp fault
- ❑ User initiated test cycles of 1, 5, 30 or 60 minutes
- ❑ Temperature compensated charger for longer battery life
- ❑ 15 minute retransfer delay

LED Indicators

Two Status LED indicators, one red and one green are provided on the control panel of all models equipped with the Spectron option.

Red Service Alert LED

Under normal operating conditions, the Service Alert LED indicator will remain off. In the event the Spectron Controller detects a malfunction, the Service Alert LED will blink at a 1 Hz. rate based on the following table:

SERVICE ALERT CODES	
●	= battery disconnected
● - ●	= battery fault
● - ● - ●	= charger fault
● - ● - ● - ●	= transfer fault
● - ● - ● - ● - ●	= lamp fault

Red Status LED Code	Description
One blink ON/pause	Battery not connected
Two blinks ON/pause	Battery fault
Three blinks ON/pause	Charger fault
Four blinks ON/pause	Transfer circuit fault
Five blinks ON/pause	Emergency Lamp Fault

Green Operating Status LED

The green Operating Status LED serves as both an AC power and a self-test indicator. During normal operation, the Operating Status LED will be illuminated indicating the presence of AC power. During all automatic or manual self-test cycles, the Operating Status LED will blink at a 1 Hz. rate.

operating status
on = ready
off = ac off
blinking = test in process

Manual Tests

Using the unit test switch, users can initiate different duration test cycles based on the following table:

Initiating Action	Test Cycle
Press test switch once	1 minute
Press test switch twice	5 minute
Press test switch 3 times	30 minute
Press test switch 4 times	60 minute

NOTE: Pressing test switch at any time after a test cycle has begun cancels remainder of test and returns unit to normal operation.


Lamp Sensing Adjustment Procedure

Procedure 1 - LZ30I-03L Model Only

LZ30I-03L model with the Spectron option are shipped from the factory with a load sensing jumper provided as shown in position "A" of the illustration below. In this position, Spectron's diagnostic circuitry can sense a failure in any of the unit's three connected lamps (2 integral and 1 remote).

IMPORTANT

If the third (remote) lighting head is not to be connected (for the purpose of extended run time or other reasons), the load sensing jumper must be reinstalled as shown in Position "B" below to prevent a false lamp failure indication. With the jumper in this position, the unit circuitry is enabled to sense a failure in either of the unit's two integral lamp heads.



Procedure 2 - All Other Remote Capacity Models

Dual-Lite remote capacity models provide sufficient battery power to operate the unit's two integral lighting heads plus one or more remote lighting fixtures. In order for the Spectron electronics module to detect a lamp failure in any of the connected fixtures, the lamp sensing circuit must be adjusted in the following manner:

NOTE: LZ30I-03L must be loaded to at least 15 watts using integral (built-in) and remote heads.

1. Depending on the total amount of connected load, one of four different "RANGE" switch settings will need to be selected (See Fig. 1). Calculate the total connected wattage load and refer to the RANGE Switch Selector Chart below to determine the appropriate setting.


IMPORTANT: In calculating total connected load, be sure to include the wattage load of the unit's two integral lighting heads.

RANGE Switch Selector Chart

Total Connected Load Wattage	Load "RANGE" Switch Setting
15	1
16 - 30	2
(N/A) 31 - 45	3
(N/A) 46 - 60	4

Operating Instructions (Cont.)

Fig. 1 **Charger Distribution Board**



7. Allow the 1 minute self-test to end (or press the test switch again to cancel self-test cycle).
8. Press the test switch again. Verify that the "Lamp Fail" LED and the "Service Alert" LED are not illuminated.

Operation

SPECTRON electronics operation is fully automatic. Accidental discharge of the unit battery prior to energization is prevented by an AC lockout circuit. The unit's green "Operating Status" LED, located on the Spectron display panel, illuminates to indicate the presence of AC power. The unit's red "Service Alert" LED will blink after application of AC power if the battery connection is not completed. During normal operation, the unit's charging circuit maintains the battery at full capacity and the Spectron Controller constantly monitors charger performance. Should the terminal voltage vary from design parameter values, the unit's red "Service Alert" LED will blink, indicating a malfunction of the battery or charger. Upon interruption of normal AC power, or brownout condition, the Spectron Controller automatically switches the emergency lighting load to the battery. Emergency power will be provided for a minimum of 90 minutes. During emergency operation, the battery is protected from deep discharge by a low voltage battery disconnect circuit. Upon return of normal AC power, a 15 minute retransfer delay holds the unit in emergency operation mode allowing utility voltage to stabilize prior to reconnection. The charger will then begin a recharge cycle. A temperature compensated float type charger is provided in LZ models utilizing Pure-Lead or Lead-Calcium batteries. This charger is designed to adjust charging voltage with changes in ambient temperature to maximize the life and performance of the unit's batteries. LZ Series models utilizing Nickel-Cadmium batteries require no temperature compensation as they utilize a constant current type charger design to maintain the unit's batteries. The charger will bring the battery to full capacity within acceptable U.L. time standards. The Spectron Controller automatically initiates a one minute discharge/diagnostic test every 28 days \pm 3.5 hours and a 30-minute discharge/diagnostic test every 6 months \pm 1 day. These tests exercise the unit's battery to optimize its capacity and allows the SPECTRON Controller to analyze emergency operation performance. Any malfunction of the unit's transfer circuit or emergency lamps will cause the red "Service Alert" LED on the unit's display panel to blink. During normal operation, all red "Service Alert" LED blinking indications of unit malfunction remain latched until corrected and retested. A manual test switch allows a user programmable 1, 5, 30 or 60-minute diagnostic/discharge test at any time. During all automatic and user initiated self-tests, the unit's green "Operating Status" LED will blink to indicate a diagnostic cycle in process.

2. Using a pen or a small screwdriver, select the proper load range by pressing the appropriate rocker switch to the left as shown in the Fig. 1 example above.
CAUTION: Only one rocker must be selected.
3. With a small screwdriver, turn the Lamp Sense Adjust potentiometer fully **clockwise**.
4. Press the unit test switch once. The emergency lamps will illuminate and a 1 minute self-test will begin. The green "Operating Status" LED on the unit's Spectron control panel will also begin to flash. The "Lamp Fail" LED located on the charger/distribution board (see Fig.1) should not be illuminated at this time. If "Lamp Fail" LED is illuminated, select the next lower load range. Example: If load range "4" was selected, select load range "3".
5. Slowly turn the "Lamp Sense Adjust" potentiometer **counterclockwise** until the "Lamp Fail" LED on the charger/distribution board illuminates. Then turn the adjustment pot back clockwise **just slightly beyond** the point where the "Lamp Fail" LED turns off to avoid false failure indications. At this point, the red "Service Alert" LED on the unit's Spectron control panel will begin a repetitive cycle of flashing 5 times followed by a pause ("lamp fault" service alert).
6. While the self-test is still in progress, disconnect one of the emergency lamp wires from the charger/distribution board. The "Lamp Fail" LED on the charger/distribution board should turn on. Reconnect the lamp wire and observe that the "Lamp Fail" LED goes out. If "Lamp Fail" LED remains illuminated, turn the "Lamp Sense Adjust" potentiometer fully clockwise and repeat step 5.

Warning:

This product contains chemicals known to the state of California to cause cancer, birth defects, and/or other reproductive harm. Thoroughly wash hands after installing, handling, cleaning, or otherwise touching this product.



Hubbell Lighting, Inc.