



United States Department of Agriculture  
Rural Development

September 20, 2005

Mr. Nick Polidori  
Connector Products Inc.  
P. O. Box 2516  
Cannaminson, New Jersey 08077

Dear Mr.Polidori:

Your application for acceptance of the S1000 automatic conductor splice has been brought to the attention of Technical Standards Committee "A" (Electric).

The Committee found your S1000 automatic splice to be acceptable on a conditional basis. The S1000 automatic splice will appear on page bx(1) of the Conditional List of Materials as follows:

**Conditional List  
bx(1)**

bx - Splice, automatic

Manufacturer	Conditions
--------------	------------

DISTRIBUTION

2 ACSR	(S1000)	1. To obtain experience.
#1 ACSR	(S1000)	2. For use on distribution systems only.
#2 AAC	(S1000)	
1/0 AAC	(S1000)	
2/0 AAC	(S1000)	
#2 AAAC	(S1000)	
1/0 AAAC	(S1000)	

This acceptance does not relieve the manufacturer of any responsibility for the satisfactory performance of the item and its conformity to guarantees, specifications, or other provisions of contracts covering its sale. This acceptance is made with the further understanding that no changes in design or workmanship affecting the quality, strength, or electrical characteristics of the item will be made without the knowledge of the Technical Standards Committees. You are also asked to notify the Technical Standards Committees of any change in manufacturing plant location or locations.

A representative list should be kept of our borrowers purchasing these S1000 automatic splices. This information will be needed at the time you apply for full acceptance after the trial period. The selection of conditionally accepted materials and equipment is at the option of the borrower.

1400 Independence Ave, SW - Washington, DC 20250-0700  
Web: <http://www.rurdev.usda.gov>

Committed to the future of rural communities.

"USDA is an equal opportunity provider, employer and lender"

To file a complaint of discrimination write USDA, Director, Office of Civil Rights, Room 326-W, Whitten Building, 14<sup>th</sup> and Independence Avenue, SW, Washington, DC 20250-9410 or call (202) 720-5964 (voice or TDD).

Mr. Nick Polidori

2

Manufacturers that desire to mention this acceptance within advertising or promotional literature are advised not to use "approved" but instead to state "accepted."

Sincerely,



HARVEY L. BOWLES  
Chair, Technical Standards  
Committee "A"  
Electric Staff Division