



United States Department of Agriculture
Rural Development

July 8, 2009

Mr. Nick Polidori
Connector Products, Inc.
5 Surrey Lane
Cinnaminson, New Jersey 08077

Dear Mr. Polidori:

Your application for Acceptance of hot line clamps has been brought to the attention of Technical Standards Committee "A" (Electric).

The Committee has granted Full Acceptance of your hotline clamps. The items will appear in the List of Materials as follows:

ap-1.1
July 2009

ap - Clamp, hot line
Copper and Copperweld-copper Conductor
(Clamps with internal springs and enclosed threads)

<u>Conductor</u>	<u>Conductor Size</u>
Copper:	6 thru 2/0
Copperweld-copper:	8A thru 2A
<u>Manufacturer</u>	
Connector Products, Inc.	HTC 100 HTC 100-6 HTC 200 HTC 200-4

1400 Independence Ave, SW • Washington, DC 20250-0700
Web: <http://www.rurdev.usda.gov>

Committed to the future of rural communities.

"USDA is an equal opportunity provider, employer and lender."
To file a complaint of discrimination write USDA, Director, Office of Civil Rights, Room 326-W, Whitten Building, 14th and Independence Avenue, SW, Washington, DC 20250-9410 or call (202) 720-5964 (voice or TDD).

ap-1.2
July 2009

ap - Clamp, hot line
ACSR with armor rods

Clamps listed below have spring action and enclosed thread chambers.

Manufacturer	Tap Conductor	Conductor Size				
		477 & 336.4	4/0 & 3/0	2/0	1/0 & 2	4
Connector Products, Inc.	Aluminum	HTC 200	HTC 100	HTC 100	HTC 100	HTC 100
		HTC 200-4	HTC 100-6	HTC 100-6	HTC 100-6	HTC 100-6
		HTC 300	HTC 200	HTC 200	HTC 200-4	
	Copper	HTC 200	HTC 100	HTC 100	HTC 100	HTC 100
		HTC 200-4	HTC 100-6	HTC 100-6	HTC 100-6	HTC 100-6
		HTC 300	HTC 200	HTC 200	HTC 200-4	

This acceptance does not relieve the manufacturer of any responsibility for the satisfactory performance of the item and its conformity to guarantees, specifications, or other provisions of contracts covering its sale. This acceptance is made with the further understanding that no changes in design or workmanship affecting the quality, strength, or electrical characteristics of the item will be made without the knowledge of the Technical Standards Committees. You are also asked to notify the Technical Standards Committees of any change in manufacturing plant location or locations.

Sincerely,



NORRIS W. NICHOLSON
Chair, Technical Standards
Committee "A"
Electric Staff Division
Rural Utilities Service