



KDER.E193573 **Grounding and Bonding Equipment**

Page Bottom

Grounding and Bonding Equipment

See General Information for Grounding and Bonding Equipment

CONTINENTAL INDUSTRIES INC

E193573

1140 N 129TH EAST AVE TULSA, OK 74116-1724 USA

Trademark and/or Tradename: "thermOweld"

Exothermic welding connection system, thermOweld Series, designations as shown below: CC-1, CC-2, CC-4, CC-6, CC-7, CC-11 Series cable to cable connections; CR-1, CR-2, CR-3 Series cable to ground rod connections; CS-1, CS-3, CS-8 Series cable to steel surface connections; CRE-1, CRE-4, CRE-6 Series cable to rebar connections; CR-1, CR-2, CR-25 Series one shot cable to ground rod connections; CB-34 for connection of conductors to 2 in. by 26, AWG SRG, BB-46 for connection of 2 in. by 26, AWG SRG to 2 in. by 26, AWG SRG.

Signal reference grid, Cat. No. SRG, followed by number from 4-20, followed by number from 1-200, followed by 12, 24, 36, 39.4, or 48.

Ground bar, Series CB, TCB, and SSB, followed by a series of numbers and letters, and CBX, TCBX, SSBX, CBRX, TCBRX.

Grounding electrodes, Cat. Nos. GRD12, GRD58, GRD-T58, GRD588-13, GRD34, GRD-T34, GRD110.

Ground mesh, Cat. No. GM or GMX, followed by X, followed by Y, followed by any number 4-24, followed by a letter or number, followed by an alpha numeric suffix representing different pigtail options where X is the width in feet and Y is the length in feet.

thermOweld Series exothermic welding molds use thermOweld Series ecothermic powder cartridges as designated on the individual mold tag.

Last Updated on 2017-11-21

Questions? Print this page Terms of Use Page Top

© 2018 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2018 UL LLC".