



CUSTOMER APPROVAL  
 APPROVED BY: \_\_\_\_\_  
 DATE: \_\_\_\_\_

**NOTES:**

1. LOGO TO BE SPECIFIED: \_\_\_\_\_.
2. THIS ASSEMBLY IS RATED FOR A STATIC DESIGN LOAD OF 8,000 LBS. [35,548 N] OVER A 10 [254] X 10 [254] AREA AND MUST PASS A MINIMUM STATIC TEST LOAD OF 12,000 LBS. [53,376 N].
3. TORSION FRAME MUST BE GROUTED AFTER IT IS ADJUSTED TO THE PROPER GRADE.

DIMENSIONS ARE IN INCHES OR MILLIMETERS IN BRACKETS UNLESS OTHERWISE NOTED.		WEIGHT	1060#	LOC	LC
BY	DATE	SCALE	481kg	LC	IC
DRN 392	5/31/16	NTS		REV	S
CHK 392	5/31/16	SCALE		REV	A
APP		SIZE	B	REV	9/16
ESR OR PROJECT NUMBER	114192	DRAWING DESCRIPTION	QUAZITE® 48 X 96 X 24 ASSEMBLY	DRAWING NUMBER	A1A4896504
		DRAWING NUMBER	114192	SHEET	1 OF 1

