



CUSTOMER APPROVAL

APPROVED BY: _____
 DATE: _____

NOTES:

1. LOGO TO BE SPECIFIED: _____.
2. THIS ASSEMBLY IS RATED FOR A STATIC DESIGN LOAD OF 15,000 LBS. [66,720 N] OVER A 10 [254] X 10 [254] AREA AND MUST PASS A MINIMUM STATIC TEST LOAD OF 22,500 LBS. [100,080 N].

| DIMENSIONS ARE IN INCHES OR MILLIMETERS IN BRACKETS UNLESS OTHERWISE NOTED. | | | | | |
|---|-----------|---------|------------------------|--|---------------|
| | BY | DATE | WEIGHT 189# 86kg | | LOC |
| DRN | <i>RJ</i> | 9/15/14 | | 546 ENGLISH ROAD ROCKY MOUNT, NC 27804 800-257-9448 www.pencell.com | LC |
| CHK | | | SCALE | A SUBSIDIARY OF HUBBELL LENOR CITY, INC. | S |
| ENG | | | NTS | DRAWING DESCRIPTION | REV |
| APR | | | SIZE | PENCELL® 24 X 36 X 24 ENCLOSURE | A |
| APR | | | B | | 9/14 |
| PROJECT NUMBER | | | | DRAWING NUMBER | |
| | | | | SHEET 1 OF 1 | DT243624PCH00 |