SUB.	REVISIONS
1	01/10/17 RELEASED FOR PRODUCTION PER DCN # 22810 RGP TLS
2	11/9/21 POB BOX OR TRI-TAP WAS POB BOX PER DCN 211026013787 RM WOV

DR. NO. M-13541 SHEET 1 OF 1









WIRING INSTRUCTIONS:

1) PLACE THE CORD GROMMET ON THE CORD AS SHOWN WITH WIRE SIZE MARKING FACING END OF WIRE.
2) USING THE WIRE STRIP GAUGE ON THE BOTTOM HOUSING, MARK AND CUT THE CABLE AND CONDUCTORS.
3) LIFT GASKET AWAY FROM HOUSING AND INSERT GROMMET IN THE GASKET "O" RING. ENSURE THE GROMMETS GROOVE FITS ALL AROUND THE GASKET "O" RING.
4) LOOSEN TERMINAL SCREWS AND CONNECT AS FOLLOWS:
- BLACK WIRE TO TERMINAL MARKED "L"
- WHITE WIRE TO TERMINAL MARKED "N"
- GREEN WIRE TO TERMINAL MARKED "G"

SECURE TERMINAL SCREWS TIGHTLY MAKING SURE CONNECTIONS ARE PROPERLY ORIENTED AND THERE ARE NO LOOSE STRANDS.
5) SLIDE GASKET INTO PLACE AND PRESS FIRMLY INTO HOUSING.
6) INSTALL CORD CLAMP WITH MATING SCREWS, ALTERNATING BETWEEN THEM UNTIL CORD CLAMP HOLDS CORD SECURELY.
7) INSTALL WIRING COVER WITH MATING SCREWS, ALTERNATING BETWEEN THEM UNTIL COVER IS TIGHTLY SECURED.

TESTING INSTRUCTIONS:

1) PLUG GFCI INTO A 120VAC POWER OUTLET.
2) PRESS RESET BUTTON.
3) VERIFY INDICATOR LENS SHOWS RED, THIS INDICATES OUTPUT VOLTAGE.
4) PRESS TEST BUTTON, VERIFY RED IN INDICATOR LENS DISAPPEARS.
5) PRESS RESET BUTTON AGAIN, VERIFY RED INDICATOR IS VISIBLE.
6) IF SO, THE GFCI IS NOW READY FOR USE.

M-13541

"IN ACCEPTING OUR DRAWINGS OR BLUEPRINTS FOR QUOTATION OR OTHER PURPOSES, YOU AGREE NOT TO DISCLOSE TO OTHERS THE IDEAS, INFORMATION OR DESIGNS THEREIN SHOWN, AND THAT YOU WILL MAKE NO USE OF OUR DRAWINGS OR BLUEPRINTS OR OF THE IDEAS, INFORMATION OR DESIGNS THEREIN SHOWN WITHOUT OUR PERMISSION."

ISO STANDARD FOR 3rd ANGLE PROJECTION

DO NOT SCALE DRAWING. USE DIMENSIONS ONLY. DIMENSIONS ARE IN INCHES UNLESS OTHERWISE SPECIFIED.

MATERIAL: N/A

FINISH: N/A

TITLE: GFCI MODULE ASSEMBLY

WIRING DEVICE-KELLEMS
HUBBELL INCORPORATED
SHELTON, CT

TOLERANCES UNLESS OTHERWISE SPECIFIED
.XX = ± .01
.XXX= ± .005
.XXXX= ±.0025
ANGLE TOL. ±1°

DR. BY	RGP	SCALE	1 / 2
CHK. BY	RGP	DATE	01/09/17
PROJECT NO.	NPD-01770		

DR. NO. M-13541

SIZE C SHEET 1 OF 1