



## **NEW!**

# INTERSYSTEM BONDING BRIDGE

RACO® / BELL® announces its new Intersystem Bonding Bridge product that meets the NEC Article 250.94 "Bonding for Other Systems" requirement. This NEC requirement calls for all telephone, cable and satellite grounding conductors be bonded to ground at a single location for residential and commercial applications.


The new bonding bridge product is designed to install the grounding conductor with a lay-in style lug and multiple mounting holes for 5 total connections. This lay-in lug feature provides for a quick and easy installation.

The RACO / BELL bonding bridge has a compact design and includes a U.V. stabilized cover that can be painted to match the aesthetics of the home or facility where it is being installed.

RACO / BELL - building bridges for electrical safety and efficiency for over 90 years!


MEETS 2008 NEC ARTICLE 250.94


### Ordering Information



#### **Material**

- One piece die cast zinc construction
- Stainless steel hardware





RACO® In	tersystem Bonding Brid	dge Orderi	ng Infor	formation - Dimensions			
Catalog	Grounding	Ship	Carte	on Dimens	sions	ITF	UPC A
Number	Conductor Range	Ctn. Qty.	L	W	Н		
RACIBB-5	#6 - #2 AWG & #14 - #4 AWG	6	5-7/8"	4-5/8"	8-1/4"	50050169986771	050169986776

#### OTHER GROUNDING PRODUCTS FROM RACO



2504 - 2505



2507 - 2508



2512 - 2513 2522 - 2523

Catalog	Pipe Size	Grounding Conductor Size	Ship	
Number	Size	Conductor Size	Ctn. Qty.	
For Bare G	round Wire - Bro	nze Alloy		
2504	1/2" - 1"	No. 2 Str./No. 10 Sol.	25	
2505	1-1/4" - 2"	No. 2 Str./No. 10 Sol.	25	
For Bare A	rmored Ground W	/ire - Bronze Alloy		
2507	1/2" - 1"	No. 6 Str./No. 10 Sol.	25	
2508	1-1/4" - 2"	No. 6 Str./No. 10 Sol.	25	
For 1/2" Ri	gid Conduit - Bro	nze Alloy		
2512	1/2" - 1"	No. 6 Str./No. 10 Sol.	25	
2522	1-1/4" - 2"	No. 6 Str./No. 10 Sol.	25	
For 3/4" Ri	gid Conduit - Bro	nze Alloy		
2513	1/2" - 1"	No. 2 Str./No. 10 Sol.	25	
2523	1-1/4" - 2"	No. 2 Str./No. 10 Sol.	25	

Distributed by:



3902 West Sample St. P.O. Box 4002 South Bend, IN 46619-4002 TEL: 574-234-7151 FAX: 574-234-0625 www.hubbell-raco.com