



AT22A19A30

Catalog ID: AT22A19A30

Prop 65 Notice

Substation Connectors

Product Details

General

| Application | Substation |
|---|----------------------|
| Connector Type | A-Frame |
| Installation Torque Recommended Run in-lb | 480 lb-in |
| Installation Torque Recommended Tap in-lb | 480 lb-in |
| Material | Aluminum Alloy, Cast |
| Material - Hardware | Aluminum Alloy |
| Physical Attribute - Number of Run Conductors | 1 |
| Physical Attribute - Number of Tap Conductors | 2 |
| Physical Attribute - Pad Orientation | 30 Degree |
| Plated | N |
| Plating Type | Unplated |
| UPC | 781810159101 |
| UPC 12 Digit | 7818101591011 |

Dimensions

| Connector Angle | 30 Degree |
|---------------------------------|-----------|
| Dimension - B Length inch | 6.00 in |
| Dimension - Height inch | 11.23 in |
| Dimension - L Length Overall mm | 301 mm |
| Dimension - Length BB inch | 4.50 in |
| Dimension - Length Overall inch | 11.87 in |

Electrical Ratings

| Rating - KVA | 230 kV |
|--------------|--------|
| | |

Conductor Related

| Conductor - AL Tube Std Run | 4 IPS |
|-----------------------------------|-----------|
| Conductor - AL Tube Std Run Range | 4 IPS |
| Conductor - AL Tube Std Tap | 2 1/2 IPS |
| Conductor - AL Tube Std Tap Range | 2 1/2 IPS |

Certifications and Compliance

| Certification - CSA Approved | No |
|------------------------------|----|
|------------------------------|----|

| Certification - ETL | No |
|------------------------------------|----|
| Certification - UL Recognized | No |
| Certification - cULus | No |
| Standards - RoHS Compliance Status | EX |
| UL Listed | No |

Logistics

| Minimum Pack Quantity | 1 |
|-----------------------|---|
|-----------------------|---|

For further technical assistance, please contact us

BURNDY Headquarters

47 East Industrial Park Drive Manchester, New Hampshire 03109

Customer Service Hours:

8 AM - 8 PM Eastern Monday-Friday Emergency Service 24-hours/365 Days Phone: 1-800-346-4175

1-603-647-5299 (International)