# **CHANCE**<sup>®</sup>

# 15 kV, 110 kV BIL, 600 A, Polymer (2 1/4" Bolt Circle) insulation, M3 Switch

By CHANCE Utility Catalog # M3D66APR

15kV, 110kV BIL, 600 A, Single-Phase Hookstick Disconnect Switch, 10" carriage bolts.

# Features

- Fully Compliant with ANSI/IEEE C37.30.1
- 15, 27 & 38kV Voltage Classes
- 110, 125, 150, 200kV BIL Insulation Levels
- 600A & 900A Current Ratings
- Porcelain and ESP Polymer Insulator Assemblies with 2.25" Bolt Circles
- Distribution Base, Serrated Slots
- Load Break Option Available

#### General

Base Type	Distribution Base, Serrated Slots
Blade Type	Solid Copper (two blade truss-member)
Cantilever Bending Strength - Routine	1,200 Lbs (5.34 kN)
Color - Insulator	Dark Gray
Contact	Silver
Description - Terminal Connectors	2 - Teminal Connectors (ATC1343, #2 - 500kcmil) w/ galvanized hardware
Insulator Type	Polymer (2 1/4″ Bolt Circle)
Material - Base	Galvanized Steel per ASTM A153
Tension Range	5000 lb
Torsional Strength	3,000 in Lbs (339 N-M)
Dimensions	
Bolt Length	10.00 in



\*Representative Image

## **Electrical Ratings**

Arc Distance - Dry	7.1" (180.3mm)
BIL	110 kV
Creep and Leakage Distance	17.2" (436.9mm)
Current Overload - 8hr Emergency	1080 A
Current Rating	600 A
Dead-Ending Rating - Working Load	8,000 Lbs
Temperature Rise - Max. at 600A	29°C
Voltage - Maximum	15 kV
Withstand Current - Short Time (10 cycles)	40kA, asymmetrical
Withstand Current - Short Time (2 sec)	25kA, symmetrical
Withstand Current - Short Time (3 sec)	16kA, symmetrical

## **Certifications and Compliance**

Industry Standard(s)	All Applicable ANSI/IEEE Standards
Logistics	
Pallet Quantity	42 EA
Standard Package	1

#### **Product Assets**

Catalogs - Hookstick Operated Switches (CA10230E\_14B) Installation Manuals - Instructions for CHANCE Type M3 Distribution Switch (P807-0198) Installation Manuals - Type M3C Single Insulator Disconnect Switch for Distribution Switching (PSP8070357) Installation Manuals - M3\_Instructions Literature - SA-M3D\_C Sales Drawings - Type M3 Switch (SA-M3D)

