




501/423

Flameproof, Increased Safety, Dust Protection and Restricted Breathing
Class - Zones
Certified ATEX / IECEx / UKEX / c CSA us



- 1 Two Independent Elastomeric Exd flameproof seals on cable outer sheath – The double seals provide superior cable retention over standard unarmoured Cable Glands
- 2 Rounded Cable entry to prevent cable damage

The 501/423 dual certified Exe/Exd cable gland incorporates two independent seals and is intended for use on non-armoured elastomer and plastic insulated cables. This cable gland may be used with braided cables where the braid and outer sheath pass into the enclosure. For Exd application the cable must be suitable inline with 60079-14. The braid must then be suitably terminated inside the enclosure. The two seals provide superior cable retention over standard unarmoured cable glands. See technical section for installation rules and regulations.

Cable Gland Selection Table

Size Ref.	Entry Thread Size 'A'		Cable Acceptance Details				'G'	Hexagon Dimensions	
	Metric	NPT*	Outer Sheath 'B'					Across Flats	Across Corners
			Standard Seal		Alternative Seal (S)				
Min.	Max.	Min.	Max.						
Os	M20 ²	½"	3.2	8.0	–	–	40.0	24.0	26.5
O	M20 ²	½"	6.5	11.9	–	–	40.0	24.0	26.5
A	M20	¾" or ½"	10.0	14.3	9.0	13.4	40.4	30.0	32.5
B	M25	1" or ¾"	13.0	20.2	9.5	15.4	44.3	36.0	39.5
C	M32	1¼" or 1"	19.5	26.5	15.5	21.2	47.2	46.0	50.5
C2	M40	1½" or 1¼"	25.0	32.5	22.0	28.0	49.5	55.0	60.6
D	M50	2" or 1½"	31.5	44.4 / 42.3 ¹	27.5	34.8	72.5	65.0	70.8
E	M63	2½" or 2"	42.5	56.3 / 54.3 ¹	39.0	46.5	64.8	80.0	88.0
F	M75	3" or 2½"	54.5	68.2 / 65.3 ¹	49.5	58.3	68.0	95.0	104.0
G	M80	3½"	67.0	73.0	–	–	68.0	106.4	115.0
H	M90	3½"	67.0	77.6	–	–	68.0	115.0	130.0
J	M100	4"	77.0	91.6	–	–	68.0	127.0	142.2

All dimensions in millimetres (except * where dimensions are in inches)

Os - F size metric entry threads are 1.5mm pitch as standard, 15mm length of thread

G - J size metric entry threads are 2mm pitch as standard, 20mm length of thread

¹Smaller value is applicable when selecting reduced NPT entry option.

²Sizes Os and O are available with an M16 thread size. For O size with M16 thread, the maximum cable outer sheath diameter is 10.9mm

Technical Data	
Material Options	Manufactured in Brass, Nickel Plated Brass or 316L Stainless Steel
Ingress Protection	IP66, IP67 and IP68 (30 metres for 7 days, special instructions apply) to IEC/EN 60529 and NEMA 4X
Enclosure Protection	IK10 to IEC 62262
Deluge Protection	Deluge Protection to DTS01
Operating Temperature	-60°C to +100°C
Applications	Suitable for use in Zone 1, Zone 21, Zone 2 and Zone 22
Approvals	
Protection Class	Ex II 2GD Ex db IIC Gb; Ex eb IIC Gb; Ex nR IIC Gc; Ex tb IIIC Db
ATEX Certificate No	CML 19ATEX1167X CML 19ATEX4507X (Ex nR)
IECEx Certificate No	CML 19.0045X CML 21.0012X (Ex nR)
UKEX Certificate No	CML 21UKEX1161X CML 21UKEX4133X (Ex nR)
Construction & Test Standards	IEC/EN 62444 (Anchorage Type B), IEC/EN 60079-0, 1, 7, 15, 31
Marine Approvals	ABS: 19-LD1876514-1-PDA BV: 43523/B0 DNV: TAE0000BS
Additional Certifications	CCC: 2020312313000319 CNEx: CNEx17 2858X EAC: No EA3C RU C-GB.HA91.B.00264/21 EQM: 20-11-27224/Q20-11-000979/NB0007 Inmetro: IEx 14.0272X India: PESO P450038 SONCAP: LCOGB049552-0500
NEC / CEC	
NEC Protection Class	Class I, Zone I, AEx eb IIC Gb; Zone 21, AEx tb IIIC Db
CEC Protection Class	Class I, Div.2 Groups ABCD; Class II Div.2, Groups EFG; Class III Ex db IIC Gb; Ex eb IIC Gb
c CSA us Certificate Number	CSA1015065
Construction & Test Standards	UL 60079-0, UL 60079-7, UL 60079-31, CSA 22.2 No: 60079-0, CSA 22.2 No: 60079-1, CSA 22.2 No: 60079-7, CSA 22.2 No: 60079-31, UL514B; UL1203; UL 2225

Ordering Information

If brass is required please omit material selection
 Format for ordering is as follows: Alternative Seal (S), add suffix S to ordering information

Cable Gland Type	Size	Thread	Material	(Optional)
423	C	M32		S
423	C	1.25	NP	S

Order Example: 423CM32S
 Please note all NPT entries should be state as a decimal
 Please refer to part code logic information page for further details on product options