HUBBELL
Power Systems

Quadri*Sil Suspension Insulator

By OHIO BRASS
Catalog # S025032S0000

25kip Standard leak, Eye Eye

*Representative Image

Features

Made from hydrophobic silicone polymer

General

Catalog Number	S025032S0000
Fitting - Ground End	Chain Eye
Fitting - Live Line End	Chain Eye
Material	Silicone Rubber
Material - End Fitting	Ductile Iron
Number of Sheds	30
Shed Style	Uniform
Strength Rating - Ultimate	25000 lb
Tensile Strength	25 kip, 5/8" (16 mm)
Tensile Strength - Routine	12,500 lbs
UPC	096359608110

Dimensions

Diameter - Shed(s)	2.9 IN
Length - Effective	45.74 in
Rod Diameter	0.625 in
Thickness - Housing	> 3MM

Electrical Ratings

Arc Distance - Dry	32.3 IN (821 MM)
Creep and Leakage Distance	83 IN (2096 MM)
Critical Impulse Flashover (CIFO) - Negative	460 kV
Critical Impulse Flashover (CIFO) - Positive	475 kV
Flashover Voltage - 60 Hz Dry	340 kV
Flashover Voltage - 60 Hz Wet	320 kV
Withstand Voltage - 60 Hz Wet	205 kV
Withstand Voltage - Lightning Impulse (Negative)	545 kV
Withstand Voltage - Lightning Impulse (Positive)	560 kV

Product Assets

Catalogs - Quadri*Sil Suspension & Line Post Insulators Catalog
Specifications - S025032S0000
Test Documents - Prototype Test Report - Quadri*Sil Suspension Insulators – 5/8" Rod

©2024 Hubbell Incorporated. All rights reserved