


© 2020 HUBBELL LIGHTING, All Rights Reserved • For more information visit our website: www.kimlighting.com • July 23, 2020 9:54 AM

ORDERING INFORMATION Cont.

Catalog Number	Height		Nominal	Wall	Bolt Circle	Bolt Circle	Bolt Square	Base Plate	Base Plate			Pole
	Feet	Meters	Shaft Dimensions	Thickness	(suggested)	(range)	(range)	Square	Thickness	Anchor bolt size	Bolt Projection	weight
RSS-A-10-40-A	10	3.0	4" round	0.125"	9"	7.5" - 10"	5.30" - 7.07"	9"	0.75"	3/4" x 30" x 3"	3.5"	52
RSS-A-12-40-A	12	3.7	4" round	0.125"	9"	7.5"-10"	5.30"-7.07"	9"	0.75"	3/4" x 30" x 3"	3.5"	62
RSS-A-14-40-A	14	4.3	4" round	0.125"	9"	7.5"-10"	5.30"-7.07"	9"	0.75"	3/4" x 30" x 3"	3.5"	72
RSS-A-16-40-A	16	4.9	4" round	0.125"	9"	7.5"-10"	5.30"-7.07"	9"	0.75"	3/4" x 30" x 3"	3.5"	83
RSS-A-18-40-A	18	5.5	4" round	0.125"	9"	7.5"-10"	5.30"-7.07"	9"	0.75"	3/4" x 30" x 3"	3.5"	93
RSS-A-20-40-A	20	6.1	4" round	0.125"	9"	7.5"-10"	5.30"-7.07"	9"	0.75"	3/4" x 30" x 3"	3.5"	103
					_	_	_			_		
RSS-A-10-40-B	10	3.0	4" round	0.188"	9"	7.5"-10"	5.30"-7.07"	9"	0.75"	3/4" x 30" x 3"	3.5"	77
RSS-A-12-40-B	12	3.7	4" round	0.188"	9"	7.5"-10"	5.30"-7.07"	9"	0.75"	3/4" x 30" x 3"	3.5"	92
RSS-A-14-40-B	14	4.3	4" round	0.188"	9"	7.5"-10"	5.30"-7.07"	9"	0.75"	3/4" x 30" x 3"	3.5"	107
RSS-A-16-40-B	16	4.9	4" round	0.188"	9"	7.5"-10"	5.30"-7.07"	9"	0.75"	3/4" x 30" x 3"	3.5"	122
RSS-A-18-40-B	18	5.5	4" round	0.188"	9"	7.5"-10"	5.30"-7.07"	9"	0.75"	3/4" x 30" x 3"	3.5"	138
RSS-A-20-40-B	20	6.1	4" round	0.188"	9"	7.5"-10"	5.30"-7.07"	9"	0.75"	3/4" x 30" x 3"	3.5"	153
RSS-A-10-50-B	10	3.0	5" round	0.188"	11"	8.0"-11"	5.66"-7.78"	10.25"	1"	1" x 36" x 4"	4.5"	97
RSS-A-12-50-B	12	3.7	5" round	0.188"	11"	8.0"-11"	5.66"-7.78"	10.25"	1"	1" x 36" x 4"	4.5"	116
RSS-A-14-50-B	14	4.3	5" round	0.188"	11"	8.0"-11"	5.66"-7.78"	10.25"	1"	1" x 36" x 4"	4.5"	135
RSS-A-16-50-B	16	4.9	5" round	0.188"	11"	8.0"-11"	5.66"-7.78"	10.25"	1"	1" x 36" x 4"	4.5"	155
RSS-A-18-50-B	18	5.5	5" round	0.188"	11"	8.0"-11"	5.66"-7.78"	10.25"	1"	1" x 36" x 4"	4.5"	174
RSS-A-20-50-B	20	6.1	5" round	0.188"	11"	8.0"-11"	5.66"-7.78"	10.25"	1"	1" x 36" x 4"	4.5"	193
RSS-A-25-50-B	25	7.6	5" round	0.188"	11"	8.0"-11"	5.66"-7.78"	10.25"	1"	1" x 36" x 4"	4.5"	242
RSS-A-20-60-C	20	6.1	6" round	0.250"	11"	9.0"-11"	6.36"-7.78"	10.25"	1"	1" x 36" x 4"	4.5"	307
RSS-A-25-60-C	25	7.6	6" round	0.250"	11"	9.0"-11"	6.36"-7.78"	10.25"	1"	1" x 36" x 4"	4.5"	384
RSS-A-30-60-C	30	9.1	6" round	0.250"	11"	9.0"-11"	6.36"-7.78"	10.25"	1"	1" x 36" x 4"	4.5"	461

NOTE Factory supplied template must be used when setting anchor bolts. Hubbell Lighting will deny any claim for incorrect anchorage placement resulting from failure to use factory supplied template and anchor bolts.



For more information about pole vibration and vibration dampers, please consult <a href="http://cdn.hubbelloutdoor.com/content/products/literature/literat




Architectural Area Lighting • 17760 Rowland Street • Rowland Height, CA 91748 • Phone: 626-968-5666 Due to our continued efforts to improve our products, product specifications are subject to change without notice. © 2020 HUBBELL LIGHTING, All Rights Reserved • For more information visit our website: www.kimlighting.com • July 23, 2020 9:54 AM



ASCE7-05 WIND MAP

FLORIDA REGION WIND MAP

180



*PRINTED WITH PERMISSION FROM ASCE

HAWAII - 105 mph PUERTO RICO - 145 mph

ASCE 7-05 wind map EPA Load Rating - 3 second gust wind speeds										
Catalog Number	85	90	100	110	120	105	145			
RSS-A-10-40-A	21.0	18.7	15.0	12.2	10.1	13.5	6.8			
RSS-A-12-40-A	16.8	14.8	11.8	9.5	7.7	10.5	5.1			
RSS-A-14-40-A	13.6	12.0	9.4	7.4	5.9	8.3	3.9			
RSS-A-16-40-A	11.1	9.7	7.5	5.8	4.5	6.6	2.9			
RSS-A-18-40-A	9.0	7.8	5.8	4.4	3.3	5.1	2.0			
RSS-A-20-40-A	7.2	6.2	4.5	3.1	2.2	3.8	1.2			
RSS-A-10-40-B	25.0	25.0	22.4	18.4	15.3	20.2	10.4			
RSS-A-12-40-B	25.0	22.3	17.9	14.5	12.0	16.1	8.1			
RSS-A-14-40-B	20.6	18.3	14.6	11.7	9.6	13.0	6.4			
RSS-A-16-40-B	17.2	15.2	12.0	9.5	7.7	10.7	5.1			
RSS-A-18-40-B	14.3	12.6	9.8	7.6	6.1	8.6	3.9			
RSS-A-20-40-B	11.8	10.3	7.9	6.0	4.7	6.9	2.9			
RSS-A-10-50-B	25.0	25.0	25.0	25.0	25.0	25.0	17.7			
RSS-A-12-50-B	25.0	25.0	25.0	24.8	20.8	25.0	14.3			
RSS-A-14-50-B	25.0	25.0	24.7	20.5	17.2	22.4	11.7			
RSS-A-16-50-B	25.0	25.0	20.7	17.1	14.3	18.8	9.7			
RSS-A-18-50-B	24.5	21.6	17.3	14.3	11.9	15.7	8.0			
RSS-A-20-50-B	20.6	18.1	14.4	11.8	9.8	13.0	6.5			
RSS-A-25-50-B	13.6	11.7	9.1	7.3	6.0	8.1	3.8			
RSS-A-20-60-C	25.0	25.0	25.0	25.0	21.5	25.0	14.8			
RSS-A-25-60-C	25.0	25.0	21.9	18.0	15.0	19.8	10.1			
RSS-A-30-60-C	21.8	19.4	15.6	12.7	10.6	14.1	6.9			

	abov 3-se the 2 Code		ed up st win rida B	d map on nds an	d	140	and the second s		150
A	ALASKA REGION	I WIND I	MAP				170	K-	<u>-</u>
<u>المحرمة</u> 13	000		110 100 90 130	and the second se	100 110 120		180	A A A A A A A A A A A A A A A A A A A	18
		ilding Code	r				-	<u> </u>	
	Catalog Number	115	120	130	140	150	160	170	180

Florida Building Code 2017 EPA Load Rating - 3 second gust wind speeds											
Catalog Number	115	120	130	140	150	160	170	180			
RSS-A-10-40-A	25.0	23.5	20.0	17.0	14.5	12.5	11.0	10.0			
RSS-A-12-40-A	21.0	19.0	16.0	13.5	11.5	9.5	9.0	8.0			
RSS-A-14-40-A	17.5	15.7	13.0	10.8	9.0	7.5	7.0	6.5			
RSS-A-16-40-A	14.2	13.0	10.5	8.5	7.0	5.8	5.0	4.5			
RSS-A-18-40-A	11.6	10.4	8.2	6.8	5.4	4.4	4.0	3.6			
RSS-A-20-40-A	9.5	8.4	6.5	5.2	4.0	3.0	2.8	2.5			
RSS-A-10-40-B	25.0	25.0	25.0	22.0	19.0	16.5	15.2	13.4			
RSS-A-12-40-B	25.0	25.0	20.8	17.6	15.1	13.0	12.0	10.6			
RSS-A-14-40-B	22.5	20.4	17.2	14.4	12.2	10.4	10.0	8.8			
RSS-A-16-40-B	18.9	17.0	14.1	11.7	9.8	8.2	7.5	7.0			
RSS-A-18-40-B	15.6	14.1	11.5	9.4	7.7	6.4	6.0	5.7			
RSS-A-20-40-B	13.0	11.6	9.3	7.5	6.0	4.8	4.0	3.5			
RSS-A-10-50-B	25.0	25.0	25.0	25.0	25.0	23.6	20.8	18.4			
RSS-A-12-50-B	25.0	25.0	25.0	25.0	22.2	19.3	16.8	14.8			
RSS-A-14-50-B	25.0	25.0	23.9	21.5	18.4	15.9	13.8	12.1			
RSS-A-16-50-B	25.0	23.8	19.6	18.0	15.4	13.2	11.4	9.9			
RSS-A-18-50-B	21.8	19.6	16.1	15.1	12.8	10.8	9.3	8.0			
RSS-A-20-50-B	18.2	16.4	14.1	12.7	10.7	9.0	7.7	6.5			
RSS-A-25-50-B	11.7	10.2	9.4	8.4	6.8	5.6	4.5	3.7			
RSS-A-20-60-C	25.0	25.0	25.0	22.1	18.8	16.1	13.9	12.0			
RSS-A-25-60-C	24.7	22.4	18.4	15.3	12.8	10.8	9.1	7.6			
RSS-A-30-60-C	18.2	16.3	13.2	10.7	8.7	7.0	5.7	4.5			

NOTES

- Allowable EPA, to determine max pole loading weight, multiply allowable EPA by 30 lbs. ٠
- The tables for allowable pole EPA are based on the ASCE 7-05 Wind Map or the Florida Region Wind Map for the 2010 Florida Building Code. The Wind Maps are intended only as a general guide and cannot be used in conjunction with other maps. Always consult local authorities to determine maximum wind velocities, gusting and unique wind conditions for each specific application
- Allowable pole EPA for jobsite wind conditions must be equal to or greater than the total EPA for fixtures, arms, and accessories to be assembled to the pole. Responsibility lies with the specifier for correct pole selection. Installation of poles without luminaires or attachment of any unauthorized accessories to poles is discouraged and shall void the manufacturer's warranty
- Wind speeds and listed EPAs are for ground mounted installations. Poles mounted on structures (such as bridges and buildings) must consider vibration and coefficient of height factors beyond this general guide; Consult local and federal standards
- Wind Induced Vibration brought on by steady, unidirectional winds and other unpredictable aerodynamic forces are not included in wind velocity ratings. Consult Hubbell Lighting's Pole Vibration Application Guide for environmental risk factors and design considerations. http://cdn.hubbelloutdoor.com/content/products/literature/lite
- Extreme Wind Events like, Hurricanes, Typhoons, Cyclones, or Tornadoes may expose poles to flying debris, wind shear or other detrimental effects not included in wind velocity ratings

Due to our continued efforts to improve our products, product specifications are subject to change without notice.



Architectural Area Lighting • 17760 Rowland Street • Rowland Height, CA 91748 • Phone: 626-968-5666 Due to our continued efforts to improve our products, product specifications are subject to change without notice. © 2020 HUBBELL LIGHTING, All Rights Reserved • For more information visit our website: www.kimlighting.com • July 23, 2020 9:54 AM

