

ANSI DESIGN TEST REPORT
Report No. EU 1512-HR-00.5
Type PDV 100 Optima
Heavy Duty Distribution Class Surge Arrester

This report records the results of the design tests made on Type PDV 100 Optima Distribution Class surge arresters in accordance with IEEE Standard C62.11-2012 "IEEE Standard for Metal Oxide Surge Arresters for AC Power Circuits (> 1kV)".

Type tests performed on PDV100 Optima arresters demonstrate full compliance with the relevant clauses of the referenced standard and apply to all Hubbell PDV100 Optima arresters of this design manufactured and assembled at the following ISO 9001:2008 certified Hubbell locations:

Hubbell Power Systems
1850 Richland Avenue, East
Aiken, South Carolina
29801

Hubbell Electric (Wuhu) Company, Ltd.
Exports Processing Zone, No 68
North Jiuhua Road, Wuhu City
Anhui Province, PR China

The above locations manufacture, assemble, and test utilizing manufacturing, quality, and calibration procedures developed from Hubbell Engineering Department Specifications. Engineering Department Specifications are controlled by Arrester Business Unit design engineering in the USA.

Saroni Brahma
Design Engineer

Dennis W. Lenk P.E.
Principal Engineer

Date: 10/31/2013

Separate reports provide details of the tests, according to the following table:

Report No.	Description	Clause	Issue Date
EU 1512-HR-01.2	Insulation Withstand	8.1	10/31/2013
EU 1512-HR-02.2	Discharge Voltage	8.2	10/31/2013
EU 1512-HR-03.2	Disc Accelerated Aging	8.5	01/22/2014
EU 1512-HR-04.2	Polymer Accelerated Aging	8.6	10/31/2013
EU 1512-HR-05.2	Salt Fog Accelerated Aging	8.7	12/16/2013
EU 1512-HR-06.2	Thermal Equivalency	7.2.2.3	10/31/2013
EU 1512-HR-07.2	Seal Integrity	8.9	10/31/2013
EU 1512-HR-08.2	Partial Discharge	8.11	10/31/2013
EU 1512-HR-09.2	High Current, Short Duration	8.12	10/31/2013
EU 1512-HR-10.2	Low Current, Long Duration	8.13	10/31/2013
EU 1512-HR-11.2	Duty Cycle	8.16	10/31/2013
EU 1512-HR-12.3	Temporary Overvoltage	8.17	10/31/2013
EU 1512-HR-13.2	Short Circuit	8.18	10/31/2013
EU 1512-HR-14.2	Disconnecter	8.21	10/31/2013
EU 1512-HR-15.2	MDCL and Moisture Ingress	8.22	10/31/2013



TYPE TEST REPORT No. EU 1512-HR-01.2

Insulation Withstand Tests on PDV 100 Optima Arrester Housing

CERTIFICATION

This is to certify that insulation withstand design tests have been successfully performed on Ohio Brass Type PDV 100 Optima Heavy Duty Distribution Class surge arresters.

A handwritten signature in black ink that reads "Saroni Brahma".

Saroni Brahma
Design Engineer

A handwritten signature in black ink that reads "Dennis W. Lenk".

Dennis W. Lenk P.E.
Principal Engineer

10/31/2013
Attachments

DESIGN TEST REPORT

Type PDV 100 Optima Distribution Class Surge Arrester

TITLE: Arrester Insulation Withstand Tests:

OBJECTIVE: To demonstrate that the voltage withstand capability of the arrester housing external insulation meets the requirements as specified in the Insulation Withstand section 8.1.2.1 of IEEE Standard C62.11-2012.

CONCLUSION: Table 1 lists PDV100 Optima arrester minimum strike distance and minimum leakage distance as well as minimum required arrester 1.2/50 impulse withstand, arrester 60 Hz 10 second wet, and bracket 60 Hz 10 second wet withstand capabilities.

All PDV100 Optima arrester ratings meet or exceed these levels of withstand voltage.

Table 1
Summary Data - Insulation Withstand Test

Catalog Number	MCOV (kV)	Rated Voltage (kV)	Total Arrester Strike Distance (in.)	Strike Distance w/ NEMA Bracket (in.)	Arrester Leakage Distance (in.)	Required Arrester 1.2 x 50 Impulse Withstand kVc	Required Arrester 10 sec wet 60 Hz Withstand kVrms	Required Bracket 10 sec wet 60 Hz Withstand kVrms
213703	2.55	3	3.8	3.4	8.5	15.8	5.0	3.8
213705	5.1	6	4.6	3.8	11.3	31.7	10.1	7.7
213708	7.65	9	5.7	4.7	14.4	46.3	15.1	11.5
213709	8.4	10	5.7	4.7	14.4	50.6	16.6	12.6
213710	10.2	12	6.6	5.1	17	60.1	20.1	15.3
213713	12.7	15	8.8	7.9	25.2	76.4	25.0	19.1
213715	15.3	18	8.8	7.9	25.2	90.2	30.2	23
213717	17	21	9.7	8.3	28.1	101.4	33.5	25.5
213720	19.5	24	12.4	11.3	36.5	121.7	38.5	29.3
213722	22	27	13.4	12.3	39.6	136.6	43.4	33
213724	24.4	30	14	13.2	42.5	150.2	48.1	36.6
213729	29	36	16.2	15.1	50.4	180.3	57.2	43.5



TYPE TEST REPORT No. EU 1512-HR-02.2

Discharge Voltage Characteristic PDV 100 Optima Distribution Arrester

CERTIFICATION

This is to certify that the discharge voltage characteristic design tests have been successfully performed on Ohio Brass Type PDV100 Optima Heavy Duty Distribution Class surge arresters.

Fayaz Khatri

Fayaz Khatri
Sr. Design Engineer

Dennis W. Lenk

Dennis W. Lenk P.E.
Principal Engineer

10/31/2013
Attachments

DESIGN TEST REPORT
Type PDV100 Optima Distribution Class Surge Arrester

Introduction: Discharge voltage tests were performed on three 36mm diameter x 42mm long MOV discs. Tests were conducted in accordance with clause 8.3 of ANSI/IEEE Standard C62.11-2012“ IEEE Standard for Metal-Oxide Surge Arresters for AC Power Circuits (>1kV)”. Individual MOV discs were subjected to 8/20 current waves with magnitudes ranging from 1.5 kA through 20 kA. In addition, Front-of-wave and switching surge discharge voltage tests were performed.

Test Results: The results of the discharge voltage tests for each MOV are summarized on Table 1, which shows the actual voltage measurements on each MOV disc at each wave shape and current level. On the right side of table 1, for each disc, the measured residual voltage levels are normalized against that disc’s 8/20 10 kA IR. For each current level/wave shape, the highest ratio has been bolded. It is this bolded factor (for each current magnitude/wave shape) that is used to verify that all protective levels derived from the 8/20 10 kA IR for each arrester rating do not exceed the guaranteed maximum discharge voltage for that rating.

Table 1
Sample Discharge Voltage Data Summary

Impulse Current (A)	Wave Shape	Discharge Voltage (kV)			Discharge Voltage Ratio		
		Sample 1	Sample 2	Sample 3	Sample 1	Sample 2	Sample 3
500	60/100	13.908	13.866	14.037	0.773	0.770	0.776
1,500	8/20	14.933	14.942	15.001	0.829	0.830	0.829
3,000	8/20	15.848	15.831	15.907	0.881	0.880	0.880
5,000	8/20	16.640	16.621	16.663	0.925	0.923	0.922
10,000	8/20	17.998	17.998	18.082	1	1	1
20,000	8/20	20.068	20.042	20.067	1.115	1.114	1.110
10,000	1/2	19.239	19.138	19.289	1.069	1.063	1.067

Conclusions: Arresters are assembled from discs accumulated within the 10 kA IR ranges that are specified for each arrester rating. To verify that catalog maximum IR levels were not exceeded, a discharge voltage ratio was established in Table 1 for each current level based on the MOV disc’s 8/20 10 kA IR. Table 2 utilizes the discharge voltage ratio factors and extrapolates the expected discharge voltage values for each arrester build and compares that with the catalog discharge voltage values for that arrester rating. As Table 2 verifies, in all cases the extrapolated IR values are less than the catalog guaranteed values. Note that the FOW values for each arrester has been corrected, per Section 8.2.2.3 of C62.11-2012 Standard, to include the affects of arrester inductive voltage drop.

Table 2
PDV100 Optima Arrester Discharge Voltage Summary

		IR Multipliers	0.776	0.83	0.881	0.925	1	1.115	1.069	FOW includ. Ldi/dt
		Impulse Wave	60/10 0	8/20	8/20	8/20	8/20	8/20	.5μsec kV	Total FOW
MCOV	Rating	I Magnitude (kA)	.5	1.5	3.0	5.0	10.0	20.0	10.0	kV
2.55	3	Prorated Sect Max IR Catalog Maximum IR	7.53 7.6	8.05 8.1	8.55 8.6	8.97 9.1	9.7 9.8	10.82 10.9	10.37 10.5	11.17 11.2
5.1	6	Prorated Sect Max IR Catalog Maximum IR	15.05 15.2	16.10 16.3	17.09 17.3	17.95 18.1	19.4 19.6	21.63 21.8	20.74 20.9	21.71 21.8
7.65	9	Prorated Sect Max IR Catalog Maximum IR	22.10 22.3	23.64 23.9	25.09 25.3	26.34 26.6	28.48 28.8	31.76 32.1	30.45 30.7	31.65 31.8
8.4	10	Prorated Sect Max IR Catalog Maximum IR	24.04 24.3	25.71 26.0	27.29 27.6	28.66 28.9	30.98 31.3	34.54 34.9	33.12 33.4	34.32 34.5
10.2	12	Prorated Sect Max IR Catalog Maximum IR	28.62 28.9	30.61 30.9	32.49 32.8	34.11 34.5	36.88 37.2	41.12 41.5	39.42 39.8	40.82 41.0
12.7	15	Prorated Sect Max IR Catalog Maximum IR	36.36 36.7	38.89 39.3	41.28 41.7	43.35 43.8	46.86 47.3	52.25 52.8	50.09 50.6	52.07 52.1
15.3	18	Prorated Sect Max IR Catalog Maximum IR	43.39 43.8	46.41 46.9	49.27 49.8	51.73 52.2	55.92 56.5	62.35 63.0	59.78 60.4	61.76 62.1
17	21	Prorated Sect Max IR Catalog Maximum IR	48.34 48.8	51.71 52.2	54.89 55.4	57.63 58.2	62.3 62.9	69.46 70.2	66.60 67.3	68.8 69.1
19.5	24	Prorated Sect Max IR Catalog Maximum IR	58.45 59.0	62.52 63.1	66.36 67.0	69.67 70.4	75.32 76.1	83.98 84.8	80.52 81.3	83.42 83.8
22	27	Prorated Sect Max IR Catalog Maximum IR	65.49 66.1	70.05 70.8	74.36 75.1	78.07 78.9	84.4 85.2	94.11 95.0	90.22 91.1	93.42 93.9
24.4	30	Prorated Sect Max IR Catalog Maximum IR	72.01 72.7	77.02 77.8	81.76 82.6	85.84 86.7	92.8 93.7	103.4 104.5	99.20 100.2	102.6 103.1
29	36	Prorated Sect Max IR Catalog Maximum IR	86.79 87.7	92.83 93.8	98.53 99.5	103.4 104.5	111.8 113.0	124.7 125.9	119.5 120.8	123.5 124.1



TYPE TEST REPORT No. EU 1512-HR-03.2

Disc Accelerated Aging PDV 100 Optima Arrester

CERTIFICATION

This is to certify that the disc accelerated aging design tests have been successfully performed on Ohio Brass Type PDV 100 Optima Heavy Duty Distribution Class Surge arresters.

A handwritten signature in black ink that reads "Saroni Brahma".

Saroni Brahma
Design Engineer

A handwritten signature in black ink that reads "Dennis W. Lenk".

Dennis W. Lenk P.E.
Principal Engineer

10/31/2013
Attachments

DESIGN TEST REPORT
PDV100 Optima Distribution Class Surge Arrester

TITLE: Accelerated aging procedure

TEST PROCEDURE: Tests were performed to measure MOV disc aging characteristics. Measured watts values are used to develop elevated voltage ratios k_c and k_r for use in proration of duty cycle and discharge current withstand test samples.

TEST SAMPLES: Six arrester sections were prepared. Three sections consisted of short (sections 1 through 3) and three sections consisted of the longest (sections 4 through 6) 36 mm diameter long MOV discs, springs, end terminals, film barrier and fiberglass/epoxy wrap using standard module construction.

TEST PROCEDURE: Tests were performed per section 8.5 of IEEE Standard C62.11-2012. Samples were placed inside a 115 °C ±2 °C. oven and energized at the assigned MCOV for 1,000 hours.

TEST RESULTS: Watts loss for each sample was measured at MCOV two hours after energization and at the completion of the 1000 hour test duration. The table below summarizes test data.

Accelerated aging test data

Sample Number	2 Hour Watts Loss @ MCOV P_{1c} (w)	1000 Hour Watts Loss @ MCOV P_{2c} (w)	Elevation Factor K_c
1	1.05	0.67	1
2	1.01	0.66	1
3	1	0.63	1
4	1.43	0.97	1
5	1.23	0.82	1
6	1.35	0.84	1

CONCLUSION: Each test sample demonstrated continually declining watts loss at MCOV. Therefore, K_c factor equals 1.0.



TYPE TEST REPORT No. EU 1512-HR-04.2
Polymer Accelerated Aging
PDV 100 Optima Arrester

CERTIFICATION

This is to certify that the polymer accelerated aging design tests have been successfully performed on Ohio Brass Type PDV 100 Optima Heavy Duty Distribution Class surge arresters.

A handwritten signature in black ink that reads "Saroni Brahma".

Saroni Brahma
Design Engineer

A handwritten signature in black ink that reads "Dennis W. Lenk".

Dennis W. Lenk P.E.
Principal Engineer

10/31/2013
Attachment

DESIGN TEST REPORT
PDV 100 Optima Distribution Class Surge arrester

TITLE: Accelerated aging tests of external polymeric insulating systems for distribution arresters.

TEST PROCEDURE: These tests were performed per clause 8.6 of IEEE Standard C62.11-2012. Accelerated aging tests by exposure to light were performed per clause 8.6.1 test method 8.6.1.2.c. Tests on polymer housing and insulating bracket material using the fluorescent UV technique described in ASTM G53-1996. Test duration was 1000 hours on three samples of each material. Accelerated aging tests by exposure to electrical stress were performed per clause 8.6.2.

TEST SAMPLES: Three PDV-100 Optima 17 kV MCOV arresters were tested. These represent the highest MCOV stress based on leakage distance and arcing distance. Tests were performed by attaching arresters to a vertical Ferris wheel, where the arresters are continuously energized. As the wheel rotates, each arrester is sequentially sprayed with a 400 ohm-centimeter water spray (Note that more severe 400 ohm-cm slurry was used in place of 2500-3100 ohm-cm specified in section. 8.6.2.3). As the energized arrester rotates around the wheel, the arrester housing goes through a dry band arcing condition. The test continues until each arrester has reached 1000 hours of energized test time. Prior to and after the 1000 hour test, each arrester is subjected to a 10 kA 8/20 discharge to confirm its electrical integrity.

The final portion of the test procedure consists of subjecting each arrester insulating bracket to 20 hours on voltage with the insulating bracket energized at MCOV. At the completion of the above tests, the arresters are examined to ensure there is no evidence of surface tracking.

ELECTRICAL EVALUATION: The following table summarizes the results of the 10 kA discharge voltage measurements made before and after the 1000 hour test.

Sample #	10 kA IR Before (kVc)	10 kA IR After (kVc)	Percent Change
1	30.37	30.51	+0.50%
2	30.24	30.23	-0.03%
3	30.41	30.43	+0.06%

CONCLUSION: Both polymer housing and insulating bracket materials passed the test requirements of clause 8.6.1.3, as there were no cracks greater than the allowed depth of .1 mm. The arresters also passed the requirements of clause 8.6.2.4, as the arrester discharge voltage changed by less than the allowed 10% as a result of the 1000 hour ferris wheel test. There were no external flashovers, punctures, or internal breakdowns during the described tests. There was no evidence of surface tracking on the arrester housings after the 1000 hour on-voltage test or on the insulating bracket after the 20 hour on-voltage test. Therefore, the PDV100 Optima successfully passed the polymer housing accelerated aging test as defined in the C62.11 standard.



TYPE TEST REPORT No. EU 1512-HR-05.2

Salt Fog Accelerated Aging Test PDV 100 Optima Arrester

CERTIFICATION

This is to certify that the salt fog accelerated aging design test has been successfully performed on Ohio Brass Type PDV 100 Optima Heavy Duty Distribution Class surge arresters.

A handwritten signature in black ink that reads "Saroni Brahma".

Saroni Brahma
Design Engineer

A handwritten signature in black ink that reads "Dennis W. Lenk".

Dennis W. Lenk P.E.
Principal Engineer

12/16/2013
Attachments

DESIGN TEST REPORT
PDV 100 Optima Distribution Class Surge Arrester

TITLE: 1000 Hour Salt Fog Exposure Test

TEST OBJECTIVE: Perform 1000 hour salt fog exposure test per section 8.7 of C62.11 – 2012 Standard.

TEST SAMPLE: Two 29 kV MCOV arresters were tested. Arrester #1 was tested with its insulating support bracket attached to the base end of the arrester. Arrester #2 was tested without the insulating support bracket.

TEST PROCEDURE: The arresters were mounted vertically inside the salt fog chamber. Prior to and after the 1000 hour test, the reference voltage and partial discharge of the sample were measured. The 1000 hour test was performed with a spray having an NaCl salt content of 10 kg/m³ per the procedure specified in section 8.7.3 of the standard

TEST RESULTS: The test arrester passed the 1000 hour salt exposure. The physical condition of the polymer housings showed no signs of surface tracking or surface erosion. There was no evidence of housing or shed punctures. The following table summarizes the results of the electrical testing.

Sample #	Reference Voltage kVc Before Salt Fog	Reference Voltage kVc After Salt Fog	Reference Voltage % Change	Partial Discharge After Salt Fog PC
1	44.5	45.0	+1.1	<1
2	45.6	46.0	+0.9	<1

Photograph #1 shows the salt-contaminated surfaces of the two arresters after completion of the 1000 hour duration salt fog test. Photograph # 2 shows a close-up view of the undamaged condition of the polymer housings. There was no evidence of surface tracking, erosion, or shed punctures.

Photograph #1



Photograph #2



CONCLUSION: The physical condition of the test arrester and the electrical testing confirmed that the PDV 100 Optima arrester successfully passed the 1000 hour salt fog exposure test.



TYPE TEST REPORT No. EU 1512-HR-6.2

VERIFICATION OF THERMALLY PRORATED SECTION

CERTIFICATION

This is to certify that verification tests demonstrating thermal equivalency were successfully performed on Ohio Brass Type PDV 100 Optima Heavy Duty Distribution Class surge arrester.

A handwritten signature in black ink that reads "Saroni Brahma".

Saroni Brahma
Design Engineer

A handwritten signature in black ink that reads "Dennis W. Lenk".

Dennis W. Lenk P.E.
Principal Engineer

10/31/2013
Attachments

DESIGN TEST REPORT
PDV 100 Optima Heavy Duty Distribution Class Surge Arrester

TITLE: Verification of thermally prorated arrester section:

INTRODUCTION: Tests were performed as required by clause 7.2.2.3 of IEEE C62.11-2012 Standard, to compare the cooling characteristics of the prorated test sections used for type tests with those of a full-size arrester unit.


PURPOSE: The purpose of this test is to verify that the thermal cooling curve for the Type PDV 100 Optima prorated sections, when internally heated, will cool slower than that of a full size 21 kV rated arrester unit.

PROCEDURE: A full size single unit 21 kV rated Type PDV 100 Optima arrester and a 12 kV and a 6 kV prorated section were heated up by applying a temporary overvoltage to the test samples. Per clause 7.2.2.3, all samples (the arrester and the prorated sections) were energized in approximately 10 minutes to a starting temperature of 140 °C, at which time the voltage was removed. The full size arrester and the two prorated sections were instrumented with (1) fiber-optic sensors located in the middle of the MOV disc stack. During the cooling portion of the test, the temperatures of the arrester and the test sections were monitored at 5 minute intervals to develop the cooling curve for each sample.

SUMMARY: As allowed in clause 7.2.2.3.5, the cooling curves for both the 12 kV and 6 kV prorated sections were adjusted higher to assure that, at no time during the 120 minute cooling period, do the section cooling curves drop below that of the full size arrester. The adjusted temperature shown for each rated section was added to the durability tests requiring a 60 degree C. preheat.

The cooling curve (Figure 1 below) confirms that the cooling rate of the 12 kV and 6 kV prorated sections is slower than that of the full size 21 kV Rated Type PDV 100 Optima arrester unit, confirming the thermal equivalency of the prorated sections to the full size arrester.

Figure 1







TYPE TEST REPORT No. EU 1512-HR-07.2

Seal Integrity Test PDV 100 Optima Arrester

CERTIFICATION

This is to certify that the seal integrity design tests have been successfully performed on Ohio Brass Type PDV 100 Optima Heavy Duty Distribution Class Surge arresters.


Saroni Brahma
Design Engineer


Dennis W. Lenk P.E.
Principal Engineer

10/31/2013
Attachments

DESIGN TEST REPORT
PDV100 Optima Distribution Class Surge Arrester

TITLE: Seal Integrity Design test

TEST SAMPLES: Tests were performed per section 8.9 of IEEE Standard C62.11-2012 on three 21 kV rated arresters.

TEST PROCEDURE: The seal integrity test consisted of the following steps:

- a) Initial Electric Test: Watts loss and IIV were measured while each arrester was energized at rated voltage.
- b) Terminal Torquing: A ¼” diameter hard lead was inserted between the wire clamp and arrester end stud on one side only. The clamping nut was torqued to 22 ft-lb.
- c) Thermal Conditioning: Each arrester was placed in a 70°C ± 3° C environment for 14 days, after which the arresters were stabilized at ambient room temperature and watts was measured.
- d) Seal Pumping: The arresters were heated to 60°C ± 3°C for one hour, then placed into a 4°C ± 3°C water bath for two hours, after which the samples were returned to the 60°C oven. Each arrester was subjected to ten repetitions of this cycle. The transfer time between media was 1-2 minutes.
- e) Final Electrical Test: Step (a) was repeated.
- f) Final Inspection: The arresters were disassembled to verify no moisture penetration was evident.

TEST RESULTS: As indicated in the following table, all arresters demonstrated adequate sealing with no evidence of internal moisture or change in watts loss or IIV.

Sample Number	Applied Voltage (kV rms)	Initial Watts Loss	Final Watts Loss	Initial Partial Discharge (picocoulombs)	Final Partial Discharge (picocoulombs)
1	21	.52	.57	0	0
2	21	.52	.57	0	0
3	21	.53	.55	0	0

CONCLUSION: The arrester watts loss increase was less than 10%, below the allowed 50% level. Internal partial discharge was unchanged after completion of the seal integrity test. In addition, disassembly revealed no evidence of internal moisture inside the test arresters. Therefore, the PDV 100 Optima arrester successfully passed the seal integrity design test.



TYPE TEST REPORT No. EU 1512-HR-08.2

Partial Discharge Test PDV 100 Optima Arrester

CERTIFICATION

This is to certify that the partial discharge design test has been successfully performed on Ohio Brass Type PDV 100 Optima Heavy Duty Distribution Class surge arrester.

A handwritten signature in black ink that reads "Saroni Brahma".

Saroni Brahma
Design Engineer

A handwritten signature in black ink that reads "Dennis W. Lenk".

Dennis W. Lenk P.E.
Principal Engineer

10/31/2013
Attachments

DESIGN TEST REPORT
PDV 100 Optima Distribution Class Surge Arrester

TITLE: Partial Discharge test

TEST PROCEDURE AND SAMPLE: Partial discharge testing was performed per section 8.11 of IEEE Standard C62.11-2012. The test was performed on a 36 kV rated, 29.0 kV MCOV PDV 100 Optima arrester.

TEST RESULTS: The measured partial discharge at 1.05 times MCOV was 0 pc.

CONCLUSION: The 36 kV rated PDV 100 Optima arrester passed test requirements as measured partial discharge was well below the allowed 10 pc test limit. As there was no extra shielding on the top end of the arrester, the RIV test was not performed.



TYPE TEST REPORT No. EU 1512-HR-09.2

HIGH CURRENT, SHORT DURATION TEST PDV 100 Optima Arrester

CERTIFICATION

This is to certify that the high current, short duration design test has been successfully performed on Ohio Brass Type PDV 100 Optima Heavy Duty Distribution Class surge arrester.

A handwritten signature in black ink that reads "Saroni Brahma".

Saroni Brahma
Design Engineer

A handwritten signature in black ink that reads "Dennis W. Lenk".

Dennis W. Lenk P.E.
Principal Engineer

10/31/2013
Attachments

DESIGN TEST REPORT
PDV 100 Optima Distribution Class Surge Arrester
High Current, Short Duration Discharge Withstand Tests:

Introduction: High current, short duration discharge withstand tests were performed per clause 8.12 IEEE Standard C62.11-2012. Tests were performed per Heavy Duty Distribution arrester requirements using a prorated test section, as required in clause 8.12.1.

Test Procedure: Per Clauses 8.12.2 and 8.12.3, test sections were subjected to two 100 kA 4-6/10-15 surges, with cooling to ambient between surges. Within 100 msec after the 2nd surge, recovery voltage is applied for 30 minutes during which the arrester's watts is monitored to demonstrate thermal stability after the 2nd lightning surge.

Test Results: Each test sample was subjected to two 100 kA, 4/10 discharges. Sufficient time was allowed between discharges for the sample to cool to ambient temperature 23 °C. Within 100 msec after the second high current discharge, the sample was energized at the prorated section recovery voltage. Watts loss was monitored over a 30 minute period demonstrating thermal stability. Figures #1 and 2 show oscillograms of the two 100 kA shots, including the start of the 30 minute recovery portion of the tests performed on Sample #1. These are typical oscillograms for the three tested samples.

Figure #1
First Shot
104.5 kA Magnitude




Figure #2
 Second Shot, Including 84 msec application of recovery voltage
 106.3 kA Magnitude




Table #1 summarizes the results of the two 100 kA shots and the watts measured during the 30 minute recovery test performed on the three test samples.

Table #1

Shot No.	Section 1 kA	Section 2 kA	Section 3 kA
1	104.5	100.8	101.4
2	106.3	103.1	99.8
N.O. Vacuum switch closed @ 84 msec			
Elapsed Time	Section 1 Watts	Section 2 Watts	Section 3 Watts
0:00:00	146.3	118.2	120.7
0:00:30	28.9	23.1	42.1
0:01:00	15.5	14.1	25.0
0:02:00	8.86	8.79	13.3
0:05:00	4.78	5.27	5.15
0:10:00	3.15	3.80	3.59
0:20:00	1.90	2.44	2.36
0:30:00	1.47	1.58	1.69

Residual voltage was measured on each test sample prior to and after the 100 kA surge duty test. Table #2 summarizes the results this testing

Table #2

Sample #	10 kA IR Before - kVc	10 kA IR After - kVc	% Change
1	18.61	19.207	+3.2
2	18.66	19.194	+2.9
3	18.76	19.249	+2.6

Conclusion: The three prorated test samples successfully completed the high current test and demonstrated thermal stability during the recovery test. The 10 kA residual voltage increase ranged from 2.6 to 3.2% confirming the electrical integrity of the test sections. Disassembly revealed no evidence of physical damage to the test sample. There was no detonation of the disconnect during the 2-shot 100 kA duty test. The PDV 100 Optima design successfully met the High Current, Short Duration requirements of a Heavy Duty Distribution Class Arrester.



TYPE TEST REPORT No. EU 1512-HR-10.2

**LOW CURRENT, LONG DURATION TEST
PDV 100 Optima Arrester**

CERTIFICATION

This is to certify that the low current, long duration design test has been successfully performed on Ohio Brass Type PDV 100 Optima Heavy Duty Distribution Class surge arrester.

Saroni Brahma

Saroni Brahma
Design Engineer

Dennis W. Lenk

Dennis W. Lenk P.E.
Principal Engineer

10/31/2013
Attachments

DESIGN TEST REPORT
PDV 100 Optima Heavy Duty Distribution Class Surge Arrester
Low Current, Long Duration Discharge Withstand Tests

Introduction: The low current, long duration discharge withstand test was performed per clause 8.13 IEEE Standard C62.11-2012. Tests were performed per Heavy Duty distribution arrester requirements using 6 kV rated test samples.

Test Samples: Per section 8.21.2.1, a ground lead disconnecter (GLD) was connected in series with each of the three LCLD 6 kV rated test samples.



Procedure: Per section 8.13.3, each test sample was subjected to six sets of three 250 A, 2000 μ s discharges. Sufficient time was allowed between sets of discharges for the section to cool to room ambient temperature. Per section 8.13.4, the 10 kA residual voltage of each MOV disc section was measured prior to and after the (18) shot LCLD test.

Results: Table 1 summarizes the results of the 18 shot test performed on the three test samples.

Table 1

Shot No.	Sample #1		Sample #2		Sample #3	
	Amps	KJ/Shot	Amps	KJ/Shot	Amps	KJ/Shot
1	254	8.38	256	8.31	256	8.40
2	256	8.32	252	8.25	252	8.25
3	254	8.30	248	8.28	252	8.35
4	258	8.33	256	8.37	256	8.38
5	254	8.25	252	8.28	252	8.23
6	256	8.33	248	8.35	248	8.26
7	258	8.37	254	8.30	256	8.37
8	250	8.24	252	8.25	254	8.31
9	252	8.39	252	8.31	250	8.28
10	255	8.31	257	8.39	259	8.38
11	255	8.37	254	8.35	255	8.37
12	250	8.28	252	8.36	253	8.39
13	259	8.44	258	8.38	257	8.32
14	254	8.35	253	8.32	253	8.34
15	250	8.29	251	8.34	249	8.26
16	257	8.38	257	8.40	257	8.39
17	256	8.41	254	8.37	255	8.41
18	252	8.36	251	8.35	254	8.40

Figures 1 and 2, respectively show oscillograms of the 1st and 18 shots performed on sample #2. These oscillograms are typical for all three test samples.



Residual voltage at 10 kA was measured prior to and following the 18-shot 250 A discharge tests. Table 2 summarizes the results of the 10 kA discharge voltage testing.

Table 2

Sample #	10 kA IR-kVc (Before)	10 kA IR-kVc (After)	10 kA IR % Change
1	18.31	18.38	+0,4
2	18.29	18.36	+0.4
3	18.27	18.36	+0.5

Conclusion: The prorated test samples successfully completed the 18-shot low current, long duration test. The sample discharge voltage increase ranged from 0.4 to 0.5%, well below the 10% change allowed in Section 8.13.4 of IEEE C62.11-2012 Standard. Disassembly revealed no evidence of physical damage to the test samples. The ground lead disconnectors did not detonate during the 18 shot test series. The PDV 100 Optima arrester successfully met the LCLD requirements of the Heavy Duty Distribution Class arrester.



TYPE TEST REPORT No. EU1512-HR-11.2

DUTY CYCLE TEST

Type PDV 100 Optima Heavy Duty Distribution Arrester

CERTIFICATION

This is to certify that the duty cycle design test has been successfully performed on the Ohio Brass Type PDV 100 Optima Heavy Duty Distribution Class surge arrester per Clause 8.16 of IEEE C62.11-2012 Standard.

Fayaz Khatri

Fayaz Khatri
Sr. Design Engineer

Dennis W. Lenk

Dennis W. Lenk P.E.
Principal Engineer

10/31/2013
Attachments

DESIGN TEST REPORT

PDV 100 Optima Heavy Duty Distribution Class Surge Arrester Duty Cycle Test

Introduction: Duty cycle tests were performed per clause 8.16 of IEEE Standard C62.11-2012. Tests were performed on the PDV 100 Optima prorated sections per Heavy Duty Distribution arrester requirements. As required by clause 8.21, tests were performed on three prorated sections with a ground lead disconnecter (GLD) to demonstrate that the GLD does not detonate during the test procedure.

Test Procedure: The prorated test section was energized at its rated voltage and subjected to twenty 10 kA, 8/20 μ s discharges spaced at 1 minute intervals. Following the twentieth impulse, the test section was placed in an oven at 64°C. After reaching 64°C, the sample was subjected to two additional 40 kA, 8/20 μ s discharges. Within 5 minutes after the second high current discharge, the sample was energized at the prorated recovery voltage. Watts loss was monitored over a 30 minute period demonstrating thermal stability.

Test Results: Tests were successfully completed on three prorated sections, each assembled with a GLD. The following data summarizes the results of tests performed on prorated section #1.

The following data summarizes the results of the duty cycle test performed on prorated section #1. Figures 1 and 2 show the 1st and 20th shot performed during the rated voltage portion of the duty cycle test.

Figure 1
1st Shot @ Rated Voltage




Figure 2





Figure 3 shows the oscillogram for the 2nd 40 kA impulse applied to the prorated section #1 during the recovery portion of the duty cycle test.

Figure 3



Figures 4 and 5 show oscillograms of the prorated section #1 grading current through the test section at time zero and 30 minutes after application of recovery voltage, demonstrating thermal recovery has occurred.

Figure 4





Figure 5



Prior to and after the duty cycle test, the 10 kA, 8/20 μ s discharge voltage was measured on the three prorated sections. Table 1 summarizes this test data.

Table 1

Section #	10 kAQ IR kVc (Before)	10 kAQ IR kVc (After)	10 kA IR % Change
1-4	36.092	36.659	1.6%
2-10	36.113	36.512	1.1%
3 -7	36.260	36.458	0.5%

CONCLUSION: The Type PDV 100 Optima prorated test samples successfully completed Duty Cycle testing and demonstrated thermal stability during the recovery test. The 10 kA discharge voltage increased 1.6%, less than the allowed 10% limit specified in Section 8.16.4 of the IEEE C62.11-2012 standard. Disassembly revealed no evidence of physical damage to the test samples. The ground lead disconnecter (GLD) on each prorated section successfully withstood the duty cycle testing without detonating. The Type PDV 100 Optima arrester successfully met the Heavy Duty Distribution arrester Duty Cycle requirements.



TYPE TEST REPORT No. EU 1512-HR-12.3

TEMPORARY OVERVOLTAGE TEST PDV 100 Optima Arrester

CERTIFICATION

This is to certify that the temporary overvoltage design test has been successfully performed on Ohio Brass Type PDV 100 Optima Heavy Distribution Class surge arrester per Clause 8.17 of the IEEE C62.11-2012 Standard.

A handwritten signature in black ink that reads "Saroni Brahma".

Saroni Brahma
Design Engineer

A handwritten signature in black ink that reads "Dennis W. Lenk".

Dennis W. Lenk P.E.
Principal Engineer

10/31/2013
Attachments

DESIGN TEST REPORT
PDV 100 Optima Heavy Distribution Class Surge Arrester
Temporary Over-Voltage Tests (TOV) Performed on Arrester Section
Without Insulating Bracket:

Introduction; Temporary over-voltage tests were performed per clause 8.17 of IEEE Standard C62.11-2012. Tests were performed per Heavy Duty distribution arrester requirements using four prorated test sections.

Test Sections: Nominally 6 and 12 kV rated prorated sections were used to facilitate testing. The short time data points were generated using 6 kV rated sections while the longer time data points used 12 kV rated sections. As both sizes of arresters were thermally equivalent to the highest rated PDV100 Optima arrester, the results of these tests cover ratings 3 - 36 kV with corresponding MCOV levels of 2.55 - 29.0 kV.


Results: Per clause 8.17.3, each prorated sample was tested within four of the six designated time ranges a - f, spanning over-voltage durations of .01 - 10,000 seconds. The tests were performed demonstrating TOV capability of the design under "no prior duty" conditions. For each TOV voltage setting, the test circuit applied voltage to the sample (preheated to 64°C) for a time duration sufficient to exceed that claimed on the "no prior duty" curve. TOV voltage was superimposed over recovery voltage such that when TOV was removed, there was no delay prior to application of recovery voltage. Recovery voltage was applied for 30 minutes to demonstrate thermal stability. As required by Section 8.17.3, Table 1 summarizes the Type PDV 100 Optima No Prior Duty TOV data points for the arrester assembled without the ground lead disconnecting (GLD) bracket.

Table 1

Time-Seconds	TOV Per Unit Times MCOV
0.02	1.705
0.1	1.622
1	1.533
10	1.450
100	1.380
1000	1.315

Figure 1 summarizes the results of the TOV testing performed on the prorated sections without the ground lead disconnecting (GLD) bracket. The single 1.456 per unit MCOV/10,000 second data point was generated using a 12 kV rated section connected in series with the GLD bracket, validating the claimed 1.45 per unit MCOV/10,000 second claim for the 12 kV arrester mounted on the GLD insulating support bracket.

Figure 1
 PDV100 Optima No Prior Duty TOV Curve



Per Section 8.17.4, the 10 kA discharge voltage for each test section was measured prior to and after TOV testing. Table 2 summarizes the results of that testing.

Table 2

Data Range	Time Seconds	Section Size	10 kA Discharge Voltage -kVc		
			Before TOV	After TOV	% Change
a	0.1	6 kV	18.166	18.580	+2.3%
c	1.2	6 kV	18.359	18.496	+0.7%
d	80	12 kV	36.176	36.145	-0.1%
f	1010	12 kV	36.070	36.208	+0.4%

Conclusion: Tests were successfully completed on four prorated samples in four specified time ranges. Each sample demonstrated thermal stability after TOV exposure. Residual voltage at 10 kA measured prior to and after the TOV test series changed much less than the allowed 10%. There was no evidence of physical damage to the test sections, validating the PDV 100 Optima arrester TOV capability claim.

DESIGN TEST REPORT

PDV 100 Optima Distribution Class Surge Arrester


TITLE: Temporary over-voltage tests (TOV) performed on arrester with insulating bracket):

OBJECTIVE: Laboratory testing reveals that attachment of the PDV 100 Optima arrester to the insulating bracket significantly improves the long time TOV capability of the arrester assembly. The degree of improvement is a function of the individual arrester ratings. The following curves show the improved TOV characteristic of the various arrester ratings mounted to the insulating bracket.


SAMPLES: Arresters ranging in rating from 3 thru 36 kV were assembled with the insulating bracket and subjected to TOV testing.

TEST RESULTS: The following tables summarize the claimable temporary overvoltage capability of the various PDV 100 Optima arrester ratings mounted on an insulating base bracket.


CONCLUSION (Arrester Mounted On Insulating Bracket): The following family of curves defines the overvoltage withstand capability of the various rated PDV 100 Optima bracket-mounted arresters when subjected to overvoltages with time durations ranging from .02 to 10,000 seconds duration.




No Prior Duty Temporary Overvoltage Curve for PDV 100 Optima 9 and 10 kV Rated Arresters Mounted On Insulating Bracket




No Prior Duty Temporary Overvoltage Curve for PDV 100 Optima 12 and 15 kV Rated Arresters Mounted on Insulating Bracket



No Prior Duty Temporary Overvoltage Curve for PDV 100 Optima 18 and 21 kV Rated Arresters Mounted on Insulating Bracket



No Prior Duty Overvoltage Capability Curve for PDV 100 Optima 24, 27, 30, and 36 kV Rated Arresters Mounted on Insulating Bracket







TYPE TEST REPORT No. EU 1512-HR-13.2

SHORT CIRCUIT TEST PDV 100 Optima Arrester

CERTIFICATION

This is to certify that the short circuit design test has been successfully performed on Ohio Brass Type PDV 100 Optima Distribution Class surge arrester.


Saroni Brahma
Design Engineer


Dennis W. Lenk P.E.
Principal Engineer

10/31/2013
Attachments

Calibration Test 10.1 kA Symmetrical RMS No Asymmetrical Requirement

Sample #	Failure Mode	Test Duration-seconds	Condition of Module/Polymer Housing After Test
5	2-Source	.204	Module Intact/Hsg Torn but in Place
6	2-Source	.209	Module Intact/Hsg Torn but in Place

Calibration Test 568 Amp Symmetrical RMS No Asymmetrical Requirement

Sample #	Failure Mode	Test Duration-seconds	Condition of Module/Polymer Housing After Test
7	2-Source	1.17	Module Intact/Hsg Torn but in Place
8	2-Source	1.22	Module Intact/Hsg Torn but in Place

CONCLUSION: The eight test arresters assembled with the longest mechanical unit met the test evaluation criteria as specified in Section 8.18.3 of IEEE C62.11-2012 Standard. In all tests, the arrester module remained intact on the insulating support bracket after the completion of each test. The flexible polymer housing wall section split, as intended, on all samples to allow venting of internal arcing gases to the outside of the arrester. In all cases, flames associated with the fault current test extinguished immediately after completion of the test, well within the allowed 2 minute duration. These tests have demonstrated the capability of the PDV100 Optima arrester design to discharge a maximum claimable 20 kA_{rms} symmetrical fault current using the test procedure defined in Section 8.18 of IEEE C62.11-2012 Standard.



TYPE TEST REPORT No. EU 1512-HR-14.2

**DISCONNECTOR TESTS
PDV 100 Optima Arrester Insulating Bracket**

CERTIFICATION

This is to certify that the disconnecter tests have been successfully performed on Ohio Brass Type PDV 100 Optima Distribution Class surge arrester insulating bracket.

A handwritten signature in black ink that reads "Saroni Brahma".

Saroni Brahma
Design Engineer

A handwritten signature in black ink that reads "Dennis W. Lenk".

Dennis W. Lenk P.E.
Principal Engineer

10/31/2013
Attachments

DESIGN TEST REPORT
PDV 100 Optima Heavy Duty Distribution Class Surge Arrester
Insulating Bracket Disconnecter Tests

OBJECTIVE: Tests were performed per clause 8.21 of IEEE Standard C62.11-2012.


TEST PROCEDURES: High current short duration, low current long duration discharge, and duty cycle tests were performed on thermally prorated test sections having the disconnecter assembly connected in series.

Disconnecter detonation testing was performed on five bracket/isolator assemblies each at 20, 80, 200, and 800 A_{rms}. In addition, detonation testing was also performed at 1 and 5 A_{rms}.

TEST RESULTS: Disconnectors did not operate when subjected to high current short duration, low current long duration discharge duty tests, and duty cycle tests.

In all cases, disconnectors separated during detonation tests at each of the required current levels.

CONCLUSION: The disconnecter passed all requirements of clause 8.21. The following figure shows the detonation curve for the PDV 100 Optima disconnecter.





TYPE TEST REPORT No. EU 1512-HR-15.2

MAXIMUM DESIGN CANTILEVER AND MOISTURE INGRESS TEST PDV 100 Optima Arrestor

CERTIFICATION

This is to certify that the maximum design cantilever (MDCL) and moisture ingress test has been successfully performed on the Ohio Brass Type PDV 100 Optima Distribution Class surge arrester.

A handwritten signature in black ink that reads "Saroni Brahma".

Saroni Brahma
Design Engineer

A handwritten signature in black ink that reads "Dennis W. Lenk".

Dennis W. Lenk P.E.
Principal Engineer


10/31/2013
Attachments

DESIGN TEST REPORT
PDV 100 Optima Distribution Class Surge Arrester

TITLE: Maximum design cantilever (MDCL) and moisture ingress test:

TEST SAMPLES: The maximum design cantilever and moisture ingress test was performed on a PDV 100 Optima 17 kV MCOV arrester, representing the longest mechanical unit. Tests were performed on this 8.6” long arrester to validate the claimed 700 inch-pound continuous cantilever rating.

TEST PROCEDURE: The test was performed per section 8.22 of C62.11-2012 standard. The test arrester was subjected to PD, watts loss, and discharge voltage tests prior to the bending moment and boiling water immersion test. The mechanical portion of the test consisted of first applying a 20 ft-lb torque to the arrester end terminals for 30 second duration. The test arrester was then placed inside a thermal cycling oven and mechanically loaded to its 700 in-lb continuous cantilever rating. The load application and test temperature is shown on the attached figure.



After completion of the mechanically loading portion of the test procedure, the water immersion portion of the bending moment test was performed per para. 8.22.3.3.a) and consists of placing the mechanically stressed arrester into a boiling salt water bath for 42 hours, after which the same is cooled to room temperature and electrical tests are repeated.

TEST RESULTS:

Sample No.	Initial Resistive Current Ir @ Uc (μA)	Final Resistive Current Ir @ Uc (μA)	Initial PD @ 1.05 times Uc (pC)	Final PD @ 1.05 times Uc (pC)	Initial 10 kA Residual Voltage kVc	Final 10 kA Residual Voltage kVc
1	.072	.080	0	0	62.57	62.87

CONCLUSION: Per Section 8.22.4, the partial discharge levels were unchanged and the resistive component of grading current changed 11%, less than the allowed 20% increase. Top end deflection measurements unchanged less than the allowed 10% as a result of the thermal cycling test. The 10 kA IR changed 0.5%, less than the allowed 10%. Visual examination revealed no evidence of mechanical damage or moisture ingress inside the arrester as a result of the test procedure. The above tests have validated the 700 inch-pound continuous cantilever rating of the base mounted PDV100 Optima arrester.