



Hubbell Power Systems, Inc.

8711 Wadsworth Road

Wadsworth, OH 4 4244

Tel: (330) 335-2361

Fax: (330) 336-9252

Document: G12-06-04

ANSI/IEEE Design Test Report

Polymer Distribution

Elbow & Parkingstand Arresters

This design test report records the results of laboratory tests performed on Elbow and Parkingstand Arresters which met or exceeded all applicable requirements of these standards:

ANSI/IEEE Standard C62.11-2005, "IEEE Standard for Metal-Oxide Surge Arresters for Alternating Current Power Circuits"

ANSI/IEEE Standard 386-2006, "IEEE Standard for Separable Insulated Connector Systems for Power Distribution Systems Above 600 V"

ANSI/IEEE Standard 592-1990, "IEEE Standard for Exposed Semiconducting Shields on High-Voltage Cable Joints and Separable Insulated Connectors"

Bas van Besouw
Principal Engineer

David E. Crotty
Senior Product Specialist

Peter Swales
Business Unit Manager



Hubbell Power Systems, Inc.

8711 Wadsworth Road

Wadsworth, OH 4 4244

Tel: (330) 335-2361

Fax: (330) 336-9252

Document: G12-06-04

Design Test Report

Reports provide details of the tests according to the following table:

Section	Description	Standard / Clause	Page
I	Arrester Insulation Withstand Tests	C62.11-2005 / 8.1	2
II	Discharge Voltage Tests	C62.11-2005 / 8.3	3
III	Accelerated Aging Test	C62.11-2005 / 8.5	10
IV	High Current, Short Duration Test	C62.11-2005 / 8.12	12
V	Low Current, Long Duration Test	C62.11-2005 / 8.13	18
VI	Duty Cycle Test	C62.11-2005 / 8.14	24
VII	Temporary Overvoltage Capability Test	C62.11-2005 / 8.15	29
VIII	Accelerated Sealing Life Test	IEEE std. 386-2006 / 7.12	32
IX	Deadfront Arrester Failure Mode Test	C62.11-2005 / 8.20	33
X	Partial Discharge Test	IEEE std. 386-2006 / 7.4	34
XI	Operating-Force Test	IEEE std. 386-2006 / 7.14	35
XII	Operating-Eye Test	IEEE std. 386-2006 / 7.15	36
XIII	Shielding Test	IEEE std. 386-2006 / 7.18	38



SECTION I

INSULATION WITHSTAND TEST: ELBOW & PARKINGSTAND ARRESTER

Introduction and Sample Preparation

The test was conducted in accordance with Section 8.1 of ANSI/IEEE Standard C62.11-2005. Insulating inserts were used in place of MOV block modules.

Test Results

Table 1 summarizes the polymer housing minimum dielectric test requirements for each arrester rating. Each arrester housing exceeded the listed 60 Hz and impulse withstand requirements summarized in table 1.

MCOV (kV)	Rated Voltage (kV)	DC for 15 minutes (kV)	60Hz Withstand 1 minute (kV RMS)	1.2/50 μ s Impulse Withstand (kV crest)
15 kV Class				
2.55	3.0	53	34.0	95.0
5.10	6.0	53	34.0	95.0
7.65	9.0	53	34.0	95.0
8.40	10.0	53	34.0	95.0
10.2	12.0	53	34.0	95.0
12.7	15.0	53	34.0	95.0
15.3	18.0	53	34.0	95.0
25 kV Class				
7.65	9.0	78	40.0	125.0
8.40	10.0	78	40.0	125.0
10.2	12.0	78	40.0	125.0
12.7	15.0	78	40.0	125.0
15.3	18.0	78	40.0	125.0
17.0	21.0	78	40.0	125.0
35 kV Class				
19.5	24.0	103	50.0	150.0
22.0	27.0	103	50.0	150.0
24.4	30.0	103	50.0	150.0

Table 1



Hubbell Power Systems, Inc.
8711 Wadsworth Road
Wadsworth, OH 4 4244
Tel: (330) 335-2361
Fax: (330) 336-9252

Document: G12-06-04

SECTION II

DISCHARGE VOLTAGE TEST: ELBOW & PARKINGSTAND ARRESTER

Sample Preparation

The discharge voltage tests were performed on a prorated sample consisting of a single 32mm diameter MOV disc element.

Test Procedure


The test was conducted in accordance with Section 8.3 of ANSI/IEEE Standard C62.11-2005 "IEEE Standard for Metal-Oxide Surge Arresters for Alternating Current Power Circuits". The disc was subjected to 8/20 μ s current waves with magnitudes ranging from 1.5 kA through 20 kA. In addition, Front-of-wave and switching surge discharge voltage tests were performed.

Test Results

The following oscillograms show the results of the individual discharge voltage tests. At the end of this section, a summary table compares the catalog protective characteristics versus the measured values extrapolated from the test data.




A.) 8/20 μ s Discharge Voltage Oscillograms: Tests were performed per Section 8.3.1 for nominal 8/20 μ s discharge current wave shapes.



1.501 kA

12.328 kV

8.2/19.6 μ s



10.173 kA


15.950 kV

8.3/18.9 μ s




Hubbell Power Systems, Inc.
8711 Wadsworth Road
Wadsworth, OH 4 4244
Tel: (330) 335-2361
Fax: (330) 336-9252

Document: G12-06-04



20.099 kA
18.424 kV
8.5/19.6 μs



40.19 kA
23.054 kV
8.1/19.6 μs

B.) Front-of-wave Oscillograms: Tests were performed per Section 8.3.2.1 for a nominal 5kA current surge with a time to voltage crest of 0.5 microseconds.



Hubbell Power Systems, Inc.


8711 Wadsworth Road

Wadsworth, OH 44244


Tel: (330) 335-2361

Fax: (330) 336-9252

Document: G12-06-04



5.120 kA
14.804 kV
2.1/4.5 μs



5.030 kA
15.119 kV
1.0/2.5 μs



Hubbell Power Systems, Inc.

8711 Wadsworth Road


Wadsworth, OH 4 4244

Tel: (330) 335-2361

Fax: (330) 336-9252

Document: G12-06-04

C.) Switching Surge Oscillograms: Tests were performed per Section 8.3.2.2 for switching surge current magnitude of 500A.



506A
11.204kV
45.0/98.5 μs



Hubbell Power Systems, Inc.
 8711 Wadsworth Road
 Wadsworth, OH 4 4244
 Tel: (330) 335-2361
 Fax: (330) 336-9252

Document: G12-06-04

**Elbow & Parkingstand Arrester
 Protective Characteristics Comparison Table**

MCOV (kV)	Rated Voltage (kV)	FOW 5kA IR		45/100μS 500A IR		8/20μS 1.5kA IR		8/20μS 3kA IR	
		Catalog Maximum (kV)	Measured (kV)	Catalog Maximum (kV)	Measured (kV)	Catalog Maximum (kV)	Measured (kV)	Catalog Maximum (kV)	Measured (kV)
15 kV Class									
2.55	3.0	12.5	11.18	8.50	8.28	9.80	9.12	10.3	9.83
5.10	6.0	25.0	22.36	17.0	16.57	19.5	18.23	20.5	19.66
7.65	9.0	33.5	30.56	23.0	22.64	26.0	24.92	28.0	26.87
8.40	10.0	36.0	31.60	24.0	23.42	27.0	25.77	29.5	27.79
10.2	12.0	50.0	44.72	34.0	33.14	39.0	36.46	41.0	39.33
12.7	15.0	58.5	52.92	40.0	39.21	45.5	43.15	48.5	46.54
15.3	18.0	67.0	61.11	46.0	45.29	52.0	49.83	56.0	53.75
25 kV Class									
7.65	9.0	33.5	30.56	23.0	22.64	26.0	24.92	28.0	26.87
8.40	10.0	36.0	31.60	24.0	23.42	27.0	25.77	29.5	27.79
10.2	12.0	50.0	44.72	34.0	33.14	39.0	36.46	41.0	39.33
12.7	15.0	58.5	52.92	40.0	39.21	45.5	43.15	48.5	46.54
15.3	18.0	67.0	61.11	46.0	45.29	52.0	49.83	56.0	53.75
17.0	21.0	73.0	64.95	49.0	48.13	55.0	52.96	60.0	57.12
35 kV Class									
19.5	24.0	92.0	83.47	63.0	61.86	71.5	68.06	76.5	73.41
22.0	27.0	100.5	91.67	69.0	67.93	78.0	74.75	84.0	80.62
24.4	30.0	108.5	97.42	74.0	72.19	81.1	79.44	88.5	85.68

Table 2



Hubbell Power Systems, Inc.
 8711 Wadsworth Road
 Wadsworth, OH 4 4244
 Tel: (330) 335-2361
 Fax: (330) 336-9252

Document: G12-06-04

**Elbow & Parkingstand Arrester
 Protective Characteristics Comparison Table**

MCOV (kV)	Rated Voltage (kV)	8/20μS 5kA IR		8/20μS 10kA IR		8/20μS 20kA IR		8/20μS 40kA IR	
		Catalog Maximum (kV)	Measured (kV)	Catalog Maximum (kV)	Measured (kV)	Catalog Maximum (kV)	Measured (kV)	Catalog Maximum (kV)	Measured (kV)
15 kV Class									
2.55	3.0	11.0	10.5	12.3	11.79	14.3	13.62	18.5	17.05
5.10	6.0	22.0	21.0	24.5	23.59	28.5	27.25	37.0	34.09
7.65	9.0	30.0	28.7	33.0	32.24	39.0	37.24	50.5	46.6
8.40	10.0	31.5	29.8	36.0	33.34	41.5	38.51	53.0	48.19
10.2	12.0	44.0	42.0	49.0	47.18	57.0	54.50	74.0	68.19
12.7	15.0	52.0	49.7	57.5	55.83	67.5	64.49	87.5	80.69
15.3	18.0	60.0	57.4	66.0	64.47	78.0	74.48	101.0	93.19
25 kV Class									
7.65	9.0	30.0	28.7	33.0	32.24	39.0	37.24	50.5	46.6
8.40	10.0	31.5	29.8	36.0	33.34	41.5	38.51	53.0	48.19
10.2	12.0	44.0	42.0	49.0	47.18	57.0	54.50	74.0	69.19
12.7	15.0	52.0	49.7	57.5	55.83	67.5	64.49	87.5	80.69
15.3	18.0	60.0	57.4	66.0	64.47	78.0	74.48	101.0	93.19
17.0	21.0	64.0	61.0	73.0	68.52	84.0	79.15	107.0	99.03
35 kV Class									
19.5	24.0	82.0	78.4	90.5	88.06	106.5	101.72	138.0	127.28
22.0	27.0	90.0	86.1	99.0	97.71	117.0	111.71	151.5	139.79
24.4	30.0	100.0	91.5	108.0	102.78	124.5	118.72	159.0	148.55

Table 3



SECTION III

ACCELERATED AGING TEST: ELBOW & PARKINGSTAND ARRESTER

Introduction

This test is performed to measure the MOV disc aging characteristic. The measured watts values are used to develop elevated voltage ratios K_c and K_r which are used in the duty cycle and discharge current withstand tests to simulate the performance of arresters that have a service life equivalent to 2000 hours at 115°C.

Sample Preparation

Three 32 mm diameter x 28 mm long discs and three 32 mm diameter x 43 mm long discs were selected for testing. The three 43 mm long discs were designated as samples #1, 2, & 3 while the 28 mm long discs were designated as samples #4, 5, & 6. The discs, which represent the longest and shortest manufactured discs, were assembled inside fiberglass-epoxy wraps and inserted inside polymer housings prior to testing.

Test Procedure

The test was performed per Section 8.5 of ANSI/IEEE C62.11-2005 Standard. The six test samples were placed inside a 115°C \pm 2°C. oven and energized at MCOV for 2000 hours. The watts loss for each sample was measured at MCOV and duty cycle rated voltage two hours after energization and at the completion of the 2000 hour test duration. Table 4 summarizes the results of the 2000 hour accelerated aging tests. All watts values were measured with the samples at 115°C.

Sample number	Watts Loss at 2Hr @ MCOV $P_{1c}(W)$	Watts Loss at 2000Hr @ MCOV $P_{2c}(W)$	Watts Loss at 2Hr @ Rating $P_{1r}(W)$	Watts Loss at 2000Hr @ Rating $P_{2r}(W)$	Elevation Factors	
					K_c	K_r
1	0.568	0.474	2.201	1.365	1.0	1.0
2	0.543	0.481	1.947	1.354	1.0	1.0
3	0.544	0.480	1.925	1.354	1.0	1.0
4	0.363	0.325	0.708	0.563	1.0	1.0
5	0.418	0.367	0.946	0.697	1.0	1.0
6	0.382	0.354	0.779	0.639	1.0	1.0

Table 4

Test Results



Hubbell Power Systems, Inc.

8711 Wadsworth Road

Wadsworth, OH 4 4244

Tel: (330) 335-2361

Fax: (330) 336-9252

Document: G12-06-04

For each test sample, the final watts loss at MCOV and rating is less than the initial watts measured. Therefore, the KC and K, factors equal 1.0. These values will be used in the duty cycle and discharge-current withstand tests.



Hubbell Power Systems, Inc.
8711 Wadsworth Road
Wadsworth, OH 4 4244
Tel: (330) 335-2361
Fax: (330) 336-9252

Document: G12-06-04

SECTION IV

HIGH CURRENT, SHORT DURATION TEST: ELBOW & PARKINGSTAND ARRESTER

Sample Preparation

This test was performed per Section 8.12 of IEEE Standard C62.11-2005. The test was performed on a thermally insulated full size 8.4kV MCOV arrester.

Test Procedure

Before and after the high current, short duration test, the 5 kA 8/20 μ s discharge voltage of the test sample was measured.

The test sample was subjected to two 65 kA 4/10 μ s discharges. Sufficient time was allowed between discharges for the sample to cool to ambient temperature (21°C).

Within 5 minutes after the second high current discharge, the sample was energized at recovery voltage. The sample watts loss was monitored until thermal stability was demonstrated.

Test Results


The arrester was subjected to two nominal 65 kA 5.2/12.4 μ s high current discharges. Table 5 summarizes the results of the 2 high current discharges.

Time	Date	Shot No.	KV	kA	Gen Charge
14:58:43	06-18-2012	1	57.014	68.642	-100.0
13:35:17	06-19-2012	2	58.176	73.579	-115.0

Table 5



The following traces show the actual current values.




Sample 1


Shot 1

Discharge Current = 68.64 kA

Discharge Voltage = 57.01 kV



Document: G12-06-04



Sample 1

Shot 2

Discharge Current = 67.46 kA

Discharge Voltage = 56.31 kV


Within 5 minutes of the second high current discharge, the sample was energized at recovery voltage (8.82 kV rms) to represent the maximum allowed watts loss disc. The sample remained energized until thermal stability was demonstrated. Table 6 summarizes the measured watts of the test sample during the recovery portion of the test.



Elapsed Time	V _{recovery} (KV _{rms})	I _t (mA)	I _r (mA)	Watts
0:00:00	8.85	-2.16	-0.30	1.50
0:00:30	8.84	-0.87	-0.38	1.54
0:01:00	8.85	-0.86	-0.39	1.49
0:02:00	8.67	-0.82	-0.34	1.31
0:05:00	8.69	-0.78	-0.27	1.16
0:10:00	8.71	0.76	0.22	1.04
0:20:00	8.63	0.83	0.19	0.89
0:30:00	8.68	0.89	0.13	0.83

Table 6

The following traces show the actual current, voltage values and wave shapes during the recovery period:




Sample #1 Recovery @ Time 0+
 Ch1: 1kV/V Ch2: 2.508 mA/V




Hubbell Power Systems, Inc.
8711 Wadsworth Road
Wadsworth, OH 44244
Tel: (330) 335-2361
Fax: (330) 336-9252

Document: G12-06-04



Sample #2 Recovery @ Time 1 Min.
Ch1: 1kV/V Ch2: 2.508 mA/V



Sample #3 Recovery @ Time 30 Min.
Ch1: 1kV/V Ch2: 2.508 mA/V

The sample 5 kA 8/20 μ s discharge voltage was measured before and after the high current test. The measured values are summarized in table 7.

**Hubbell Power Systems, Inc.**

8711 Wadsworth Road

Wadsworth, OH 4 4244

Tel: (330) 335-2361

Fax: (330) 336-9252

Document: G12-06-04

	Sample No.	Shot	Time	Date	IR (KVc)	I (kA)	Chg KV	Result
Before	1	1	11:27:52	6/20/2012	29.643	5.003	37.7	Pass
After	1	1	11:31:50	4/14/2012	30.986	5.037	37.2	Pass

Table 7Test Summary

The test sample successfully completed the high current test and demonstrated thermal stability during the recovery test. The 5 kA 8/20 μ s discharge voltage changed by an acceptable +4.5%, within the allowable 10% acceptance limit. Disassembly revealed no evidence of physical damage to the test sample. Therefore, the test sample has successfully fulfilled the high current, short duration requirements of the Dead-Front Type Arrester.



SECTION V

LOW CURRENT, LONG DURATION TEST: ELBOW & PARKINGSTAND ARRESTER

Sample Preparation

This test was performed per Section 8.12 of IEEE Standard C62.11-2005. The test was performed on a thermally insulated 8.4kV MCOV Arrester.

Test Procedure

Before and after the low current, long duration test, the 5 kA 8/20 μ s discharge voltage of the test sample was measured.

The test sample was subjected to three groups of six consecutive operations followed by one group of two operations with a time interval between consecutive operations of 50-60 seconds. Sufficient time was allowed between groups of discharges for the sample to cool to ambient temperature (21°C). Prior to the 19th operation, the sample was heated to 85 °C. Within 5 minutes after the 20th low current discharge, the sample was energized at recovery voltage. The samples watts loss was monitored until thermal stability was demonstrated.

Test Results

The arrester was subjected to twenty long duration surges of 2000 microseconds. Current magnitude ranged from 75.4 to 83.8 amps during the 20 shot test. Table 8 summarizes the results of the 20 discharges.

Shot No.	Spec No.	Time	Date	KVc	Amps	KJ/Shot	Result	Trace
1	3	15:22:30	07 May 12	21.572	83.8	4.39	Pass	
2	3	15:23:16	07 May 12	21.613	80.0	4.22	Pass	1
3	3	15:24:01	07 May 12	21.655	77.5	4.11	Pass	
4	3	15:24:47	07 May 12	21.738	77.9	4.12	Pass	
5	3	15:25:32	07 May 12	21.842	80.4	4.26	Pass	
6	3	15:26:18	07 May 12	21.822	78.6	4.16	Pass	
7	3	16:40:12	07 May 12	21.655	81.5	4.28	Pass	
8	3	16:40:57	07 May 12	21.717	79.4	4.19	Pass	
9	3	16:41:43	07 May 12	21.759	76.5	4.07	Pass	
10	3	16:42:28	07 May 12	21.801	78.2	4.15	Pass	
11	3	16:43:13	07 May 12	21.863	78.2	4.14	Pass	
12	3	16:43:59	07 May 12	21.884	75.9	4.05	Pass	




13	3	09:15:47	08 May 12	21.655	81.4	4.28	Pass	
14	3	09:16:32	08 May 12	21.738	79.3	4.19	Pass	
15	3	09:17:18	08 May 12	21.759	78.4	4.16	Pass	
16	3	09:18:03	08 May 12	21.801	78.6	4.18	Pass	
17	3	09:18:48	08 May 12	21.842	78.4	4.17	Pass	
18	3	09:19:34	08 May 12	21.863	78.2	4.18	Pass	
Specimen preheated to 85±5 °C Prior to shot 19								
19	3	08:12:02	14 May 12	21.895	75.8	4.06	Pass	
20	3	08:12:48	14 May 12	21.978	75.4	4.03	Pass	2

Table 8

15:23 Monday, May 07, 2012

Serial Number : IDA0200151



Main : 10 µs/pt	Sweep Time: 100k smpl/s	Cur2-GND: -1.4627 A	Cur2-Cur1: -81.494 A
Zoom : 1 µs/pt		Cur2-TRIG: 3.51 ms	Cur2-Cur1: 2.05 ms
Zoom Only 10:1	Memory: 5000	Trig: Edge Pretrigger: 10.0%	Bandwidth: 1MHz
		CH2 DC Pos UL: +22.969 A LL: +12.437 A	


Shot 2. Trace 1



Hubbell Power Systems, Inc.
8711 Wadsworth Road
Wadsworth, OH 4 4244
Tel: (330) 335-2361
Fax: (330) 336-9252

Document: G12-06-04

09:18 Tuesday, May 08, 2012 Serial Number : IDA0200151



Main : 10 μ s/pt	Sweep Time:	Cur2-GND: -1.1754 A	Cur2-Cur1: -79.613 A
Zoom : 1 μ s/pt	100k smpl/s	Cur2-TRIG: 3.51 ms	Cur2-Cur1: 2.05 ms
Zoom Only	Memory:	Trig: Edge Pretrigger: 10.0%	Bandwidth:
10:1	5000	CH2 DC Pos UL: +22.969 A LL: +12.437 A	1MHz

Shot 20, Trace 2


Within 5 minutes of the twentieth long duration discharge, the sample was energized at the recovery voltage (8.66 kV rms) to represent the maximum allowed watts loss disc. The sample remained energized until thermal stability was demonstrated. Table 9 summarizes the measured watts loss of the test sample during the recovery portion of the test.



Data No.	Elapsed Time	KV _{RMS}	It (mA)	Ir (mA)	Watts	Trace
1	00:00:00	8.747	-1.19	-0.70	1.14	3
2	00:00:30	8.740	-1.22	-1.00	1.07	
3	00:01:00	8.741	-1.17	-0.80	1.02	4
4	00:02:00	8.740	-0.75	-0.60	0.92	
5	00:04:00	8.512	-0.70	-0.57	0.75	
6	00:06:00	8.498	-0.71	-0.54	0.70	
7	00:08:00	8.519	-0.69	-0.54	0.67	
8	00:10:00	8.485	-0.69	-0.55	0.63	
9	00:12:00	8.503	-0.68	-0.54	0.61	
10	00:14:00	8.503	-0.68	-0.52	0.59	
11	00:16:00	8.475	-0.69	-0.52	0.56	
12	00:18:00	8.481	-0.69	-0.52	0.54	
13	00:20:00	8.469	-0.67	-0.51	0.52	
14	00:22:00	8.473	-0.67	-0.50	0.50	
15	00:24:00	8.475	-0.69	-0.51	0.49	
16	00:26:00	8.486	-0.69	-0.49	0.47	
17	00:28:00	8.481	-0.67	-0.52	0.46	
18	00:30:00	8.493	-0.67	-0.50	0.45	5

Table 9

The following traces show the actual current, voltage values and wave shapes during the recovery period:



Trace 3

Recovery @ Time 0 – 1kV/V 2.508mA/V



Hubbell Power Systems, Inc.


8711 Wadsworth Road

Wadsworth, OH 44244

Tel: (330) 335-2361


Fax: (330) 336-9252

Document: G12-06-04



Trace 4

Recovery @ 1 Min. - 1kV/V 2.508mA/V



Trace 5

Recovery @ 30 Min. - 1kV/V 2.508mA/V



The sample's 5 kA 8/20 μ s discharge voltage was measured before and after the high current test. The measured values are summarized in table 10.

	Sample No.	Shot	Time	Date	IR (KVc)	I (kA)	Chg KV	Result
Before	1	1	10:58:17	4/25/2012	29.374	5.182	37.25	Pass
After	1	1	15:15:07	5/11/2012	29.180	5.116	37.25	Pass

Table 10

Test Summary

The test sample successfully completed the low current, long duration test and demonstrated thermal stability during the recovery test. The 5 kA 8/20 μ s discharge voltage changed an acceptable -0.7%, within the allowable 10% acceptance limit. Disassembly revealed no evidence of physical damage to the test sample. Therefore, the test sample successfully fulfilled the low current, long duration requirements of the Dead-Front Type Arrester.



Hubbell Power Systems, Inc.
8711 Wadsworth Road
Wadsworth, OH 4 4244
Tel: (330) 335-2361
Fax: (330) 336-9252

Document: G12-06-04

SECTION VI

DUTY CYCLE TEST: ELBOW & PARKINGSTAND ARRESTER

Sample Preparation

This test was performed per Section 8.14 of IEEE Standard C62.11-2005. The test was performed on a thermally insulated full size 8.4kV MCOV arrester.

Test Procedure

Before and after the duty cycle test, the 5 kA 8/20 μ s discharge voltage of the test sample was measured.

The test sample was then energized at duty cycle rated voltage and subjected to (20) 5 kA 8/20 μ s discharges spaced one minute apart. Per the standard, these 5 kA discharges were electrically timed to occur at approximately 60° before 60-Hz voltage crest.

The test sample was preheated to 85 °C and was subjected to two additional 5 kA 8/20 μ s duty cycle operations while energized at MCOV. After the twenty-second duty cycle operation, the sample was energized at recovery voltage. The sample's watts loss was monitored until thermal stability was demonstrated.



Test Results

The arrester was energized at duty cycle rated voltage (14.2 kV rms) and subjected to (20) 5 kA surges spaced one minute apart. Table 11 summarizes the results of the 20 surges.

Shot No.	Shot Time	Impulse (kA)	V _{RATED} (KV _C)	60Hz I _t (mA)	60Hz I _r (mA)	Watts
1	9:34:35	5.1	14.191	0.96	0.25	0.63
2	9:35:26	5.1	14.201	-0.87	-0.15	0.66
3	9:36:17	5.1	14.226	0.91	0.28	0.77
4	9:37:07	5.0	14.201	1.32	0.23	0.80
5	9:37:58	5.0	14.181	3.48	0.33	0.72
6	9:38:49	4.9	14.201	0.97	0.33	0.89
7	9:40:30	4.9	14.224	2.08	0.35	0.90
8	9:41:21	5.0	14.211	1.36	0.30	0.97
9	9:42:12	5.0	15.469	-3.53	-0.18	0.88
10	9:43:02	4.9	15.441	3.49	0.28	0.98
11	9:43:53	5.0	14.287	3.49	0.33	0.78
12	9:44:43	4.9	14.210	-1.04	-0.30	1.15
13	9:45:34	4.9	14.173	3.53	0.30	0.81
14	9:46:24	4.9	14.240	1.00	0.30	1.23
15	9:47:15	5.0	14.199	-0.85	-0.35	1.23
16	9:48:06	5.0	14.154	1.40	0.45	1.26
17	9:48:56	5.0	14.188	1.14	0.35	1.30
18	9:49:47	4.9	14.146	1.02	0.40	1.34
19	9:50:38	4.9	14.105	-1.13	-0.25	1.31
20	9:51:28	4.9	14.140	-0.98	-0.28	1.35

Table 11

After successful completion of the (20) shot test, the sample was preheated to 85 °C and subjected to an additional two 5 kA surges spaced one minute apart with the sample energized at MCOV (8.5 kV rms). Table 12 summarizes the results of the 2 additional surges.

Shot No.	Shot Time	Impulse (kA)	V _{RECOVERY} (KV _{RMS})	60Hz I _t (mA)	60Hz I _r (mA)	Watts
21	13:04:36	4.8	8.472	-0.63	-0.08	0.36
22	13:05:27	4.7	8.479	1.27	0.15	0.42

Table 12




The sample was energized after the 22nd 5 kA surge at recovery voltage until thermal stability was demonstrated. The recovery voltage represents the maximum allowed watts loss disc. Table 13 summarizes the results of the recovery voltage test.

Elapsed Time	V _{RECOVERY} (KV _{RMS})	60Hz I _t (mA)	60Hz I _r (mA)	Watts
0:00:00	8.50	-0.62	-0.100	0.41
0:00:30	8.51	-0.64	-0.075	0.37
0:01:00	8.49	-0.62	-0.050	0.35
0:02:00	8.49	-0.63	-0.075	0.33
0:05:00	8.49	-0.63	-0.025	0.30
0:10:00	8.48	-0.61	-0.050	0.28
0:20:00	8.47	-0.62	-0.050	0.25
0:30:00	8.50	-0.61	-0.050	0.22

Table 13

The following traces show the actual current, voltage values and wave shapes during the recovery period:



Sample #1 Recovery @ Time 0+
Ch1: 1kV/V Ch2: 2.508 mA/V



Hubbell Power Systems, Inc.


8711 Wadsworth Road

Wadsworth, OH 44244

Tel: (330) 335-2361


Fax: (330) 336-9252

Document: G12-06-04



Sample #1 Recovery @ Time 1 Min.

Ch1: 1kV/V Ch2: 2.508 mA/V



Sample #1 Recovery @ Time 30 Min.

Ch1: 1kV/V Ch2: 2.508 mA/V

The sample 5 kA 8/20 μ s discharge voltage was measured before and after the duty cycle test. The measured values are summarized in Table 14.

**Hubbell Power Systems, Inc.**

8711 Wadsworth Road

Wadsworth, OH 4 4244

Tel: (330) 335-2361

Fax: (330) 336-9252

Document: G12-06-04

	Sample No.	Shot	Time	Date	IR (KVc)	I (kA)	Chg KV	Result
Before	1	1	11:27:52	4/09/2012	29.553	4.962	37.2	Pass
After	1	1	10:05:38	4/14/2012	30.986	5.037	37.2	Pass

Table 5**Conclusion**

The test sample successfully completed the duty cycle test and demonstrated thermal stability while being energized at recovery voltage. The 5 kA 8/20 μ s discharge voltage changed an acceptable +4.8%, within the allowable 10% acceptance limit. Disassembly revealed no evidence of physical damage to the test sample. Therefore, the test sample has successfully fulfilled the duty cycle requirements of the Dead-Front Type Arrester.



SECTION VII

TEMPORARY OVERVOLTAGE CAPABILITY TEST: ELBOW & PARKINGSTAND ARRESTER

Introduction

This test was performed per Section 8.15 of IEEE Standard C62.11-2005. The tests were performed on (5) prorated test samples, selected to represent the most severe design conditions, i.e., the minimum allowed discharge voltage level.

Test Procedure

Per Section 8.15.1, each prorated sample is tested in (5) different time ranges ranging from (.01-.1 seconds) to (1,001-10,000 seconds). Per Section 8.15.3.1, the test is performed to demonstrate the temporary overvoltage (TOV) capability of the design under "no prior duty" conditions. For each TOV voltage setting, the test circuit applies the voltage to the sample (preheated to 85°C) for time duration sufficient to exceed that claimed on the "no prior duty" curve. Within 100 milliseconds after the TOV, a recovery voltage is applied for (30) minutes to demonstrate thermal stability. The recovery voltage level takes into account the maximum allowed watts loss for the sample.

Prior to and after the TOV application, the 5 kA discharge voltage of each sample is measured.

Test Results

Tests were successfully completed on (5) prorated samples in (5) specified time ranges. Each sample demonstrated thermal stability after TOV exposure. Table 15 summarizes the TOV values for the Normal Duty Elbow/Parkingstand arrester for "no prior" conditions.

Sample Number	TOV Duration (Seconds)	No Prior Duty TOV (Per Unit MCOV)
3, 5, 7, 8 & 9	0.1	1.63
3, 5, 7, 8 & 9	1.	1.53
3, 5, 7, 8 & 9	3.0	1.49
3, 5, 7, 8 & 9	10	1.45
3, 5, 7, 8 & 9	1000	1.35

Table 65

Table 16 summarizes the 5 kA discharge voltages of the samples measured prior to and after the TOV test.



Hubbell Power Systems, Inc.

8711 Wadsworth Road

Wadsworth, OH 4 4244

Tel: (330) 335-2361

Fax: (330) 336-9252

Document: G12-06-04

Sample Number	5 kA IR Before TOV Test	5 kA IR After TOV Test	Percent Change
3	27.186 kV	27.300	0.42
5	26.960 kV	27.316	1.32
7	26.977 kV	27.300	1.20
8	27.009 kV	27.396	1.43
9	27.025 kV	27.283	0.95

Table 16


Conclusion

The 5 kA 8/20 μ s discharge voltage of each sample changed less than 1.43% as a result of the TOV duty. Disassembly revealed no evidence of physical damage caused by the TOV testing. The individual test points successfully confirmed the claimed TOV capability curve. The following curve plots the individual "no prior duty" TOV data points on the TOV capability curve.



Hubbell Power Systems, Inc.
8711 Wadsworth Road
Wadsworth, OH 44244
Tel: (330) 335-2361
Fax: (330) 336-9252

Document: G12-06-04





SECTION VIII

ACCELERATED SEALING LIFE TEST: ELBOW & PARKINGSTAND ARRESTER

Introduction

This test was performed per Section 7.12 of IEEE/ANSI Standard 386-2006, "IEEE Standard for Separable Insulated Connector Systems for Power Distribution Systems Above 600V".

Test Setup

Per section 7.12 the four arresters were placed in an oven having 121°C temperature for three weeks. The four samples were then removed and operated once using the operating eye.

The four arresters were then subjected to 50 cycles of being placed for 1 hour in a 121°C temperature oven then removed and submerged in 25°C ± 10°C conductive water for 1 hour.

At the completion of the 50th cycle the samples were measured for watts loss and subjected to the design impulse test (section 7.5.3 of IEEE/ANSI Standard 386-2006).

Test Results

No change in watts loss was observed and no puncture or flashover occurred when the samples were subjected to impulse. Table 17 summarizes the watts loss @ 8.4 kV before and after the Accelerated Sealing Life Test

Sample Number	Initial Watts	Final Watts
9	0.15	0.15
10	0.16	0.15
19	0.18	0.17
20	0.16	0.16

Table 17

Conclusion

The four samples successfully completed the accelerated sealing life test. They did not demonstrate an appreciable change in watts loss and did not flashover or puncture when subjected to impulse testing.



SECTION IX

DEADFRONT ARRESTER FAILURE MODE: ELBOW & PARKINGSTAND ARRESTER FAULT CURRENT WITHSTAND TESTS

Introduction

This test was performed per Section 8.20 of IEEE Standard C62.1 1-2005.

Test Setup

Per section 8.20, the arresters were prefaulted. An open-circuit test voltage was then applied within 5 minutes of the prefault mode. Three arresters were tested with a fault current of 500 A for a minimum duration of 0.3 s (20 c), three additional arresters were tested at a fault current of 10,000 A for a minimum duration of 0.17 s (10 c).

Test Results

Each of the samples subjected to fault current expelled the valve elements intact with release of the bottom grounded cap.

Conclusion

None of the samples tested fractured or ejected valve elements through the body of the arrester, therefore demonstrating conformance to the test standard. Oscillographic recordings showed conformance with the current magnitude and duration specified.



Hubbell Power Systems, Inc.
8711 Wadsworth Road
Wadsworth, OH 4 4244
Tel: (330) 335-2361
Fax: (330) 336-9252

Document: G11-12-01

SECTION X

PARTIAL DISCHARGE TEST: ELBOW & PARKINGSTAND ARRESTER

Introduction

This test was performed per Section 7.4 of ANSI/IEEE Standard 386-2006 "IEEE Standard for Separable Insulated Connector Systems for Power Distribution Systems Above 600 V".

Test Setup

The equipment and test methods conformed to ANSI/IEEE Standard 386-2006 "IEEE Standard for Separable Insulated Connector Systems for Power Distribution Systems Above 600 V" requirements. Prior to the test, the CDO 77A Corona Detector was calibrated by the Calibrator Type CDO-CI.

Test Results

A background noise level of 0.5 pC was measured prior to energization of the arrester housing. The arrester housing noise level met the requirements of IEEE 386 -2006.

Conclusion

The Arresters successfully passed the internal ionization and PD tests by not exceeding the allowed 3 pC test limit. Internal ionization tests are routinely performed on all arresters.



SECTION XI

OPERATING-FORCE TEST: ELBOW & PARKINGSTAND ARRESTER

Introduction

This test was performed per Section 7.14 of IEEE/ANSI Standard 386-2006 "IEEE Standard for Separable Insulated Connector Systems for Power Distribution Systems Above 600 V". The tests were performed on (4) assembled arresters.

Test Procedure

Per Section 7.14 each of the assembled elbow arresters were tested at -20°C, +25°C and + 65°C. Each test consisted of closing the connector and then reopening it within 10 min. The force was applied to the operating eye parallel to the axis of the probe at a rate of 5 in/min.

Test Results

Table 18 summarizes the results of the operating-force tests.

Sample Number	Open -20°C (lbf)	Open +25°C (lbf)	Open +65°C (lbf)	Close -20°C (lbf)	Close +25°C (lbf)	Close +65°C (lbf)
1	191	136	125	136	167	131
2	184	74	106	167	169	124
3	177	151	85	148	162	84
4	177	121	85	168	164	144

Table 18

Conclusion

The arresters performed within the 50 lbf — 200 lbf force requirement of IEEE/ANSI 386-2006 Standard.



SECTION XII

OPERATING-EYE TEST: ELBOW ARRESTER

Introduction

This test was performed per Section 7.15 of IEEE/ANSI Standard 386-2006 “IEEE Standard for Separable Insulated Connector Systems for Power Distribution Systems Above 600 V”.

Setup

Two separate tests were run on the operating-eye. For both tests, the elbow arresters were tested at ambient temperature. Four elbow arresters were used in each of the two tests. For the first test, four elbow arresters were pulled in tension until they broke. The purpose of this test was to obtain maximum load values for the operating-eye. For the second test, four elbow arresters were tested for partial discharge. Then the operating-eye was loaded with both a tensile force and a rotational force using a live-line tool. The purpose of this test was to demonstrate that the operating-eye could support a 14 N-m (120 lbf-in) rotational force, along with a static operating force of 2,224 N (500 lbf).

Procedure

Test 1: Average Maximum Load

- Using the large cantilever, the 1,500 lb. tensile load cell, and the Omega meter, a tensile force was gradually applied to the operating-eye of each elbow arrester in the direction of normal operation.
- The tensile force was gradually applied until the operating-eye failed by pulling away from the elbow arrester.
- The maximum load was then recorded from the Omega meter for each elbow arrester and an average load was calculated.

Summary

Each of the operating-eyes was able to hold more than the required 2,224 N-m (500 lbf). Table 19 summarizes the results of the operating eye maximum force tests.

Sample Number	Maximum Force (lbf)
1	822.4
2	896.2
3	896.2
4	892.5

Table 19



Hubbell Power Systems, Inc.

8711 Wadsworth Road

Wadsworth, OH 4 4244

Tel: (330) 335-2361

Fax: (330) 336-9252

Document: G11-12-01

Test 2: Static Force and Rotational Force Test

Partial discharge levels were obtained for four elbow arrester housings. A tensile load of 500 lbf was applied to each of the elbow arresters normal to the operating eye for 60 seconds. Using the Chance live line tool a rotational force of 120 lbf-in (14 N-m) was applied in both clockwise and counterclockwise directions. Partial discharge levels were then obtained for all four elbow arresters and compared to the initial values.

Summary

Some distortion of the operating-eye was evident, however, this was acceptable because the elbow was still serviceable and passed partial discharge requirements of the standard.



SECTION XIII

SHIELDING TEST: ELBOW & PARKINGSTAND ARRESTER

Introduction

This test was performed per Section 7.18 of ANSI/IEEE Standard 386-2006, "IEEE Standard for Separable Insulated Connector Systems for Power Distribution Systems Above 600 V". Section 7.18 states that the test procedure shall be in accordance with IEEE Std. 592-1990, "IEEE Standard for Exposed Semiconducting Shields on High Voltage Cable Joints and Separable insulated Connectors".

Test Setup

The equipment and test methods conformed to IEEE Std. 592-1990, "IEEE Standard for Exposed Semiconducting Shields on High-Voltage Cable Joints and Separable insulated Connectors".

Shield Resistance Test: Arrester shield resistance measurements were performed on unaged samples and air oven aged samples ($121^{\circ}\text{C} \pm 5^{\circ}\text{C}$ for 504 hours). The measurements were taken with the test specimen temperature at $20^{\circ}\text{C} \pm 5^{\circ}\text{C}$ and at $90^{\circ}\text{C} \pm 5^{\circ}\text{C}$. *Fault-Current Initiation Test:* Test samples were prepared in accordance with section 4.3 of IEEE Std. 592-1990.

Test Results

Each sample, before and after aging, measured less than 5000Ω shield resistance. Samples also successfully initiated two consecutive fault-current arcs to ground as specified in 4.3. Table 20 summarizes the results of the shielding tests.

Sample Number	R @ 20°C Unaged	R @ 90°C Unaged	R @ 20°C Aged 504Hrs. @ 121°C	R @ 90°C Aged 504Hrs. @ 121°C
1	440 Ω	396 Ω	460 Ω	1,330 Ω
2	610 Ω	620 Ω	584 Ω	1,330 Ω

Table 20

Conclusion

The housings meet the requirements of IEEE Std. 592-1990 by demonstrating shield resistance less than 5000Ω and capability of initiating two consecutive fault-current arcs to ground as specified in 4.3.